

ENERGY CONSUMPTION SUMMARY

By THORNTON TOMASETTI, INC.

	Elect Cons. (kWh)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
Alternative 1				
Primary heating				
Primary heating	34,013	12.9 %	116,085	348,291
Other Htg Accessories	5,990	2.3 %	20,444	61,337
Heating Subtotal	40,003	15.2 %	136,529	409,628
Primary cooling				
Cooling Compressor	5,200	2.0 %	17,747	53,248
Tower/Cond Fans		0.0 %	0	0
Condenser Pump		0.0 %	0	0
Other Clg Accessories	8,492	3.2 %	28,983	86,959
Cooling Subtotal....	13,692	5.2 %	46,731	140,207
Auxiliary				
Supply Fans	34,341	13.0 %	117,205	351,649
Pumps	45,143	17.2 %	154,075	462,270
Stand-alone Base Utilities	29,617	11.3 %	101,081	303,274
Aux Subtotal....	109,101	41.4 %	372,361	1,117,193
Lighting				
Lighting	38,187	14.5 %	130,331	391,032
Receptacle				
Receptacles	62,269	23.7 %	212,522	637,631
Cogeneration				
Cogeneration		0.0 %	0	0
Totals				
Totals**	263,250	100.0 %	898,474	2,695,691

* Note: Resource Utilization factors are included in the Total Source Energy value .

** Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

ENERGY CONSUMPTION SUMMARY

By THORNTON TOMASETTI, INC.

	Elect Cons. (kWh)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
Alternative 2				
Primary heating				
Primary heating	100,956	26.5 %	344,564	1,033,794
Other Htg Accessories	368	0.1 %	1,257	3,773
Heating Subtotal	101,325	26.6 %	345,821	1,037,567
Primary cooling				
Cooling Compressor	17,725	4.7 %	60,494	181,500
Tower/Cond Fans	2,834	0.7 %	9,672	29,018
Condenser Pump		0.0 %	0	0
Other Clg Accessories	612	0.2 %	2,088	6,266
Cooling Subtotal....	21,170	5.6 %	72,254	216,783
Auxiliary				
Supply Fans	69,340	18.2 %	236,658	710,046
Pumps		0.0 %	0	0
Stand-alone Base Utilities	45,098	11.8 %	153,921	461,808
Aux Subtotal....	114,439	30.0 %	390,579	1,171,854
Lighting				
Lighting	82,007	21.5 %	279,889	839,750
Receptacle				
Receptacles	62,269	16.3 %	212,522	637,631
Cogeneration				
Cogeneration		0.0 %	0	0
Totals				
Totals**	381,209	100.0 %	1,301,065	3,903,584

* Note: Resource Utilization factors are included in the Total Source Energy value .

** Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

Energy Cost Budget / PRM Summary

By THORNTON TOMASETTI, INC.

Project Name:	Date: June 10, 2015
City:	Weather Data: BRUNSWICK NAS, Maine

Note: The percentage displayed for the "Proposed/ Base %" column of the base case is actually the percentage of the total energy consumption.

* Denotes the base alternative for the ECB study.

		* Alt-2 ASHRAE Baseline 90.1-0			Alt-1 Proposed Building		
		Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh	Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh
Lighting - Conditioned	Electricity	260.2	20	76	124.8	48	36
Lighting - Unconditioned	Electricity	19.7	2	6	5.6	28	2
Space Heating	Electricity	346.8	27	741	136.5	39	82
Space Cooling	Electricity	61.3	5	107	46.7	76	92
Pumps	Electricity	0.0	0	0	154.1	0	67
Heat Rejection	Electricity	9.6	1	10	0.0	0	0
Fans - Conditioned	Electricity	229.9	18	55	117.2	51	47
Receptacles - Conditioned	Electricity	212.5	16	62	212.5	100	62
Stand-alone Base Utilities	Electricity	153.9	12	67	101.1	66	55
Total Building Consumption		1,293.9			898.5		

		* Alt-2 ASHRAE Baseline 90.1-0	Alt-1 Proposed Building
Total	Number of hours heating load not met	0	0
	Number of hours cooling load not met	22	23

		* Alt-2 ASHRAE Baseline 90.1-0		Alt-1 Proposed Building	
		Energy 10 ⁶ Btu/yr	Cost/yr \$/yr	Energy 10 ⁶ Btu/yr	Cost/yr \$/yr
Electricity		1,293.9	48,069	898.5	33,380
Total		1,294	48,069	898	33,380

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Cooling Plant: GEOTHERMAL PLANT

Sizing method: Peak
 Heat rejection type: None
 Secondary distribution pump: Var vol chill water pump
 Secondary pump consumption: 5 kW
 Thermal storage type: GLHE designed for 3F (2C) TD wellfield
 Thermal storage capacity: 480 gal/ton
 Thermal storage schedule: Heatpump

Geothermal Loop

TLoop Ent Bldg:	Custom	Flow scheme:	Fully mixed
TLoop schedule:	P14009-GRND TEMP PROFILE	Loop fluid glycol:	0%
Flow rate:	120.00% of condenser flow rate	Heat exchanger approach:	0°F
Loop pump	90.1 Pump Riding the Pump Curve		
Pump F.L. rate:	10.87kw		

Equipment tag: HP-01	Cooling Type: P14009-WSHP-D	GEOTHERMAL PLANT
-----------------------------	------------------------------------	-------------------------

Operating Mode Capacity	Energy Rate	Pumps Type	Full Load Consumption
Cooling: 10.0 tons Heat recovery: 113.0 Mbh Tank charging: Tank charging & heat recovery:	20.8600 EER (compressor only) 2.7700 COP (compressor only)	Chilled water: Var vol chill water pump Condenser water: None Heat recovery or aux cond: None Free cooling: None	0.21 kW
Heat Rejection and Thermal Storage		Equipment Options	
Heat rejection type: None Thermal storage type: None T-storage capacity: 144 gal/ton T-storage schedule: Heatpump	Sequencing type: Parallel Demand lim priority: Dsn chilled water delta T: 10 °F Dsn cond water delta T: 10 °F	Free clg type: None Fluid cooler type: Load shed econ: no Evap precooling: no Hot gas reheat No	Energy source: BACKUP-HEAT Reject cond heat: Ground Loop Cond. heat to plant: BACKUP-HEAT Equip schedule: Available (100%)
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water: Outside air Condenser Water: None	CHW - 45f - 55f None	0°F 0°F	

Equipment tag: HP-02	Cooling Type: P14009-WSHP-D	GEOTHERMAL PLANT
-----------------------------	------------------------------------	-------------------------

Operating Mode Capacity	Energy Rate	Pumps Type	Full Load Consumption
Cooling: 10.0 tons Heat recovery: 113.0 Mbh Tank charging: Tank charging & heat recovery:	20.8600 EER (compressor only) 2.7700 COP (compressor only)	Chilled water: Var vol chill water pump Condenser water: None Heat recovery or aux cond: None Free cooling: None	0.21 kW
Heat Rejection and Thermal Storage		Equipment Options	
Heat rejection type: None Thermal storage type: None T-storage capacity: 144 gal/ton T-storage schedule: Heatpump	Sequencing type: Parallel Demand lim priority: Dsn chilled water delta T: 10 °F Dsn cond water delta T: 10 °F	Free clg type: None Fluid cooler type: Load shed econ: no Evap precooling: no Hot gas reheat No	Energy source: BACKUP-HEAT Reject cond heat: Ground Loop Cond. heat to plant: BACKUP-HEAT Equip schedule: Available (100%)
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water: Outside air Condenser Water: None	CHW - 45f - 55f None	10°F 0°F	

Equipment tag: HP-03	Cooling Type: P14009-WSHP-D	GEOTHERMAL PLANT
-----------------------------	------------------------------------	-------------------------

Operating Mode Capacity	Energy Rate	Pumps Type	Full Load Consumption
Cooling: 10.0 tons Heat recovery: 113.0 Mbh Tank charging: Tank charging & heat recovery:	20.8600 EER (compressor only) 2.7700 COP (compressor only)	Chilled water: Var vol chill water pump Condenser water: None Heat recovery or aux cond: None Free cooling: None	0.21 kW
Heat Rejection and Thermal Storage		Equipment Options	

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Heat rejection type: None Thermal storage type: None T-storage capacity: 144 gal/ton T-storage schedule: Heatpump	Sequencing type: Parallel Demand lim priority: Dsn chilled water delta T: 10 °F Dsn cond water delta T: 10 °F	Free clg type: None Fluid cooler type: Load shed econ: no Evap precooling: no Hot gas reheatNo	Energy source: BACKUP-HEAT Reject cond heat: Ground Loop Cond. heat to plant: BACKUP-HEAT Equip schedule: Available (100%)
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water:Outside air	CHW - 45f - 55f	10°F	
Condenser Water:None	None	0°F	

Equipment tag: HP-04

Cooling Type: P14009-WSHP-D

GEOHERMAL PLANT

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption
Cooling:	10.0 tons	20.8600 EER (compressor only)	Chilled water:	Var vol chill water pump	0.21 kW
Heat recovery:	113.0 Mbh	2.7700 COP (compressor only)	Condenser water:	None	
Tank charging:			Heat recovery or aux cond:	None	
Tank charging & heat recovery:			Free cooling:	None	

Heat Rejection and Thermal Storage

Equipment Options

Heat rejection type: None Thermal storage type: None T-storage capacity: 144 gal/ton T-storage schedule: Heatpump	Sequencing type: Parallel Demand lim priority: Dsn chilled water delta T: 10 °F Dsn cond water delta T: 10 °F	Free clg type: None Fluid cooler type: Load shed econ: no Evap precooling: no Hot gas reheatNo	Energy source: BACKUP-HEAT Reject cond heat: Ground Loop Cond. heat to plant: BACKUP-HEAT Equip schedule: Available (100%)
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water:Outside air	CHW - 45f - 55f	10°F	
Condenser Water:None	None	0°F	

Equipment tag: HP-05

Cooling Type: P14009-WSHP-D

GEOHERMAL PLANT

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption
Cooling:	10.0 tons	20.8600 EER (compressor only)	Chilled water:	Var vol chill water pump	0.21 kW
Heat recovery:	113.0 Mbh	2.7700 COP (compressor only)	Condenser water:	None	
Tank charging:			Heat recovery or aux cond:	None	
Tank charging & heat recovery:			Free cooling:	None	

Heat Rejection and Thermal Storage

Equipment Options

Heat rejection type: None Thermal storage type: None T-storage capacity: 144 gal/ton T-storage schedule: Heatpump	Sequencing type: Parallel Demand lim priority: Dsn chilled water delta T: 10 °F Dsn cond water delta T: 10 °F	Free clg type: None Fluid cooler type: Load shed econ: no Evap precooling: no Hot gas reheatNo	Energy source: BACKUP-HEAT Reject cond heat: Ground Loop Cond. heat to plant: BACKUP-HEAT Equip schedule: Available (100%)
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water:Outside air	CHW - 45f - 55f	10°F	
Condenser Water:None	None	0°F	

Equipment tag: HP-06

Cooling Type: P14009-WSHP-D

GEOHERMAL PLANT

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption
Cooling:	10.0 tons	20.8600 EER (compressor only)	Chilled water:	Var vol chill water pump	0.21 kW
Heat recovery:	113.0 Mbh	2.7700 COP (compressor only)	Condenser water:	None	
Tank charging:			Heat recovery or aux cond:	None	
Tank charging & heat recovery:			Free cooling:	None	

Heat Rejection and Thermal Storage

Equipment Options

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Heat rejection type: None	Sequencing type: Parallel	Free clg type: None	Energy source: BACKUP-HEAT
Thermal storage type: None	Demand lim priority:	Fluid cooler type:	Reject cond heat: Ground Loop
T-storage capacity: 144 gal/ton	Dsn chilled water delta T: 10 °F	Load shed econ: no	Cond. heat to plant: BACKUP-HEAT
T-storage schedule: Heatpump	Dsn cond water delta T: 10 °F	Evap precooling: no	Equip schedule: Available (100%)
		Hot gas reheat No	
Reset Based On	Reset Curve	Max Reset TD	
Chilled Water: Outside air	CHW - 45f - 55f	10°F	
Condenser Water: None	None	0°F	

Heating Plant: BACKUP-HEAT

Sizing method: Block
Cogeneration type: None
Secondary distribution pump: Var vol chill water pump
Secondary pump consumption: 5 kW
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: BACKUP-HEAT	Heating Type: P14009-BACKUP	BACKUP-HEAT
Heating capacity:	Thermal storage type: None	
Energy rate: 100.00 % Effic.	Thermal storage capacity: 0 ton-hr	
	Thermal storage schedule: Storage	
Hot water pump type: VV Hot Water Circ	Equipment schedule: Available (100%)	
Hot water pump cons: 1.26 Ft Water	Demand limiting priority:	

Heating Plant: UNCONDITIONED

Sizing method: Peak
Cogeneration type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: UNCONDITIONED	Heating Type: Default electric resistance	UNCONDITIONED
Heating capacity:	Thermal storage type: None	
Energy rate: 100.00 % Effic.	Thermal storage capacity: 0 ton-hr	
	Thermal storage schedule: Storage	
	Equipment schedule: Available (100%)	
	Demand limiting priority:	

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Base Utilities

Plant assigned to: Stand-alone Type: Exhaust Fan	Description: Exhaust Fans Demand limiting priority:	Schedule: On 100% Hourly demand: 0.10 kW
Plant assigned to: Stand-alone Type: DHW CIRC PUMP	Description: DHW CIRC PUMP Demand limiting priority:	Schedule: On 100% Hourly demand: 0.02 kW
Plant assigned to: Stand-alone Type: Parking lot lights	Description: EXTERIOR LIGHTING Demand limiting priority:	Schedule: Parking lot lights Hourly demand: 1.17 kW
Plant assigned to: Stand-alone Type: Elevator	Description: Elevator Demand limiting priority:	Schedule: P14009- Elevator Hourly demand: 18.65 kW
Plant assigned to: Stand-alone Type: P14009-DHW	Description: P14009-DHW Demand limiting priority:	Schedule: Hot water - Low rise office Hourly demand: 0.18 gpm

Miscellaneous accessories

Plant assigned to: GEOTHERMAL PLANT Equipment tag: All	Type: Var vol chill water pump Description: Var vol chill water pump	Schedule: Available (100%) Energy: 1.46 kW
---	---	---

**ENTERED VALUES
PLANTS**
By THORNTON TOMASETTI, INC.

Cooling Plant: 901-07 Min ACHP AllHeat SP < 65

Sizing method: Peak
Heat rejection type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr
Thermal storage schedule: Off (0%)

Geothermal Loop			
TLoop Ent Bldg:	None	Flow scheme:	Fully mixed
TLoop schedule:	None	Loop fluid glycol:	0%
Flow rate:	100.00% of condenser flow rate	Heat exchanger approach:	0°F
Loop pump	None		
Pump F.L. rate:	0.00ft water		

Equipment tag: 901-07 Min ACHP AllHeat SP < 65 Cooling Type: 90.1-07 Min ACHP AllHeat SP < 65 MBh 901-07 Min ACHP AllHeat SP < 65

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption
Cooling:		11.0000 Packaged EER	Chilled water:	None	
Heat recovery:	14.4 Mbh/ton	7.7000 Packaged EER	Condenser water:	None	
Tank charging:			Heat recovery or aux cond:	None	
Tank charging & heat recovery:			Free cooling:	None	
Heat Rejection and Thermal Storage			Equipment Options		
Heat rejection type: 90.1 Min Air Cooled Condenser		Sequencing type: Single	Free clg type: None		Energy source: H901-07 Min ACHP - SP < 65 MBh
Thermal storage type: None		Demand lim priority:	Fluid cooler type: None		Reject cond heat: Heat Reject.Equip
T-storage capacity: 0 ton-hr		Dsn chilled water delta T: 12 °F	Load shed econ: no		Cond. heat to plant:
T-storage schedule: Storage		Dsn cond water delta T: 0 °F	Evap precooling: no		Equip schedule: Available (100%)
			Hot gas reheat No		
Reset Based On	Reset Curve	Max Reset TD			
Chilled Water:None	None	0°F			
Condenser Water:None	None	0°F			

Package energy breakout	Primary fan	Secondary fan	Exhaust fan	Optional ventilation fan	Condenser fan
Included in full load energy rate	Yes	No	No	No	Yes

Apply same fans for heat recovery energy breakout: Yes

Cooling Plant: 901-07 Min ACHP Elec SS/SP 065-135

Sizing method: Peak
Heat rejection type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr
Thermal storage schedule: Off (0%)

Geothermal Loop			
TLoop Ent Bldg:	None	Flow scheme:	Fully mixed
TLoop schedule:	None	Loop fluid glycol:	0%
Flow rate:	100.00% of condenser flow rate	Heat exchanger approach:	0°F
Loop pump	None		
Pump F.L. rate:	0.00ft water		

Equipment tag: 901-07 Min ACHP Elec SS/SP 065-135 Cooling Type: 90.1-07 Min ACHP Elec SS/SP 65-135 MBh 901-07 Min ACHP Elec SS/SP 065-135

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption
Cooling:		11.0000 Packaged EER	Chilled water:	None	
Heat recovery:	14.4 Mbh/ton	3.3000 Packaged COP	Condenser water:	None	
Tank charging:			Heat recovery or aux cond:	None	
Tank charging & heat recovery:			Free cooling:	None	
Heat Rejection and Thermal Storage			Equipment Options		

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Heat rejection type: 90.1 Min Air Cooled Condenser	Sequencing type: Single	Free clg type: None	Energy source: H901-07 Min ACHP - SP < 65 MBh
Thermal storage type: None	Demand lim priority:	Fluid cooler type: None	Reject cond heat: Heat Reject.Equip
T-storage capacity: 0 ton-hr	Dsn chilled water delta T: 12 °F	Load shed econ: no	Cond. heat to plant:
T-storage schedule: Storage	Dsn cond water delta T: 0 °F	Evap precooling: no	Equip schedule: Available (100%)
		Hot gas reheat No	
<u>Reset Based On</u>	<u>Reset Curve</u>	<u>Max Reset TD</u>	
Chilled Water:None	None	0°F	
Condenser Water:None	None	0°F	

Package energy breakout	Primary fan	Secondary fan	Exhaust fan	Optional ventilation fan	Condenser fan
Included in full load energy rate	Yes	No	No	No	Yes

Apply same fans for heat recovery energy breakout: Yes

ENTERED VALUES PLANTS

By THORNTON TOMASETTI, INC.

Heating Plant: H901-07 Min ACHP - SP < 65 MBh

Sizing method: Peak
Cogeneration type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: H901-07 Min ACHP - SP < 65 MBh

Heating Type: Default electric resistance

H901-07 Min ACHP - SP < 65 MBh

Heating capacity:
Energy rate: 100.00 % Effic.

Thermal storage type: None
Thermal storage capacity: 0 ton-hr
Thermal storage schedule: Storage

Equipment schedule: Available (100%)
Demand limiting priority:

Heating Plant: H901-07 Min ACHP Elec SS/SP 065-135

Sizing method: Peak
Cogeneration type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: H901-07 Min ACHP Elec SS/SP 065-135

Heating Type: Default electric resistance

H901-07 Min ACHP Elec SS/SP 065-135

Heating capacity:
Energy rate: 100.00 % Effic.

Thermal storage type: None
Thermal storage capacity: 0 ton-hr
Thermal storage schedule: Storage

Equipment schedule: Available (100%)
Demand limiting priority:

Heating Plant: H901-07 SYSTEM 10 ELECTRIC RES

Sizing method: Peak
Cogeneration type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: H901-07 SYSTEM 10 ELECTRIC RES

Heating Type: Default electric resistance

H901-07 SYSTEM 10 ELECTRIC RES

Heating capacity:
Energy rate: 100.00 % Effic.

Thermal storage type: None
Thermal storage capacity: 0 ton-hr
Thermal storage schedule: Storage

Equipment schedule: Available (100%)
Demand limiting priority:

**ENTERED VALUES
PLANTS**
By THORNTON TOMASETTI, INC.

Heating Plant: UNCONDITIONED

Sizing method: Peak
Cogeneration type: None
Secondary distribution pump: None
Secondary pump consumption: 0 Ft Water
Thermal storage type: None
Thermal storage capacity: 0 ton-hr

Equipment tag: UNCONDITIONED	Heating Type: Default electric resistance	UNCONDITIONED
Heating capacity: Energy rate: 100.00 % Effic.	Thermal storage type: None Thermal storage capacity: 0 ton-hr Thermal storage schedule: Storage Equipment schedule: Available (100%) Demand limiting priority:	

Base Utilities

Plant assigned to: Stand-alone Type: Exhaust Fan	Description: Exhaust Fans Demand limiting priority:	Schedule: On 100% Hourly demand: 0.10 kW
Plant assigned to: Stand-alone Type: DHW CIRC PUMP	Description: DHW CIRC PUMP Demand limiting priority:	Schedule: On 100% Hourly demand: 0.02 kW
Plant assigned to: Stand-alone Type: Parking lot lights	Description: EXTERIOR LIGHTING Demand limiting priority:	Schedule: Parking lot lights Hourly demand: 4.19 kW
Plant assigned to: Stand-alone Type: Elevator	Description: Elevator Demand limiting priority:	Schedule: P14009- Elevator Hourly demand: 18.65 kW
Plant assigned to: Stand-alone Type: P14009-DHW	Description: P14009-DHW Demand limiting priority:	Schedule: Hot water - Low rise office Hourly demand: 0.23 gpm

Miscellaneous accessories

Plant assigned to: 901-07 Min ACHP AllHeat SP < 65 Equipment tag: All	Type: None Description:	Schedule: Off (0%) Energy: 0.00 kW
--	----------------------------	---------------------------------------

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	HP-07	
System Type:	Single Zone	
User-entered Total Fan Power	0.07	kW
Design Supply Airflow	406	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	406
Main Exhaust	0.00	406
Room Exhaust	0.00	0
Return	0.00	406
Ventilation	0.00	0

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.38	Bhp
Total Fan Power	0.35	kW
Fan Ratio Override	4.792	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
HP-07	FC Centrifugal Const Vol	Primary fan	Zone	406	0.07	0.35

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-01	
System Type:	Single Zone	
User-entered Total Fan Power	0.18	kW
Design Supply Airflow	1,017	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	1,017
Main Exhaust	0.00	1,017
Room Exhaust	0.00	0
Return	0.00	1,045
Ventilation	0.00	204

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.96	Bhp
Total Fan Power	0.86	kW
Fan Ratio Override	4.773	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-01	FC Centrifugal Const Vol	Primary fan	Zone	1,017	0.18	0.86

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-02	
System Type:	Single Zone	
User-entered Total Fan Power	0.17	kW
Design Supply Airflow	948	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	948
Main Exhaust	0.00	948
Room Exhaust	0.00	0
Return	0.00	969
Ventilation	0.00	204

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.89	Bhp
Total Fan Power	0.81	kW
Fan Ratio Override	4.769	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-02	FC Centrifugal Const Vol	Primary fan	Zone	948	0.17	0.81

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-03	
System Type:	Single Zone	
User-entered Total Fan Power	0.21	kW
Design Supply Airflow	1,185	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	1,185
Main Exhaust	0.00	1,185
Room Exhaust	0.00	0
Return	0.00	1,225
Ventilation	0.00	184
PRM Fan Motor Efficiency	84.00	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	1.11	Bhp
Total Fan Power	0.99	kW
Fan Ratio Override	4.687	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-03	FC Centrifugal Const Vol	Primary fan	Zone	1,185	0.21	0.99

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-04	
System Type:	Single Zone	
User-entered Total Fan Power	0.11	kW
Design Supply Airflow	610	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	610
Main Exhaust	0.00	610
Room Exhaust	0.00	0
Return	0.00	625
Ventilation	0.00	31

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.57	Bhp
Total Fan Power	0.52	kW
Fan Ratio Override	4.752	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-04	FC Centrifugal Const Vol	Primary fan	Zone	610	0.11	0.52

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-05	
System Type:	Single Zone	
User-entered Total Fan Power	0.27	kW
Design Supply Airflow	1,522	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	1,522
Main Exhaust	0.00	1,522
Room Exhaust	0.00	0
Return	0.00	1,587
Ventilation	0.00	130
PRM Fan Motor Efficiency	84.00	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	1.43	Bhp
Total Fan Power	1.27	kW
Fan Ratio Override	4.686	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-05	FC Centrifugal Const Vol	Primary fan	Zone	1,522	0.27	1.27

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-06	
System Type:	Single Zone	
User-entered Total Fan Power	0.08	kW
Design Supply Airflow	468	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	468
Main Exhaust	0.00	468
Room Exhaust	0.00	0
Return	0.00	486
Ventilation	0.00	54
PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.44	Bhp
Total Fan Power	0.40	kW
Fan Ratio Override	4.738	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-06	FC Centrifugal Const Vol	Primary fan	Zone	468	0.08	0.40

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-07	
System Type:	Single Zone	
User-entered Total Fan Power	0.07	kW
Design Supply Airflow	375	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	375
Main Exhaust	0.00	375
Room Exhaust	0.00	0
Return	0.00	375
Ventilation	0.00	174

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.35	Bhp
Total Fan Power	0.32	kW
Fan Ratio Override	4.746	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-07	FC Centrifugal Const Vol	Primary fan	Zone	375	0.07	0.32

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-08	
System Type:	Single Zone	
User-entered Total Fan Power	0.11	kW
Design Supply Airflow	604	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	604
Main Exhaust	0.00	604
Room Exhaust	0.00	0
Return	0.00	618
Ventilation	0.00	54

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.57	Bhp
Total Fan Power	0.51	kW
Fan Ratio Override	4.750	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-08	FC Centrifugal Const Vol	Primary fan	Zone	604	0.11	0.51

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-09	
System Type:	Single Zone	
User-entered Total Fan Power	0.39	kW
Design Supply Airflow	2,186	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	2,186
Main Exhaust	0.00	2,186
Room Exhaust	0.00	0
Return	0.00	2,259
Ventilation	0.00	319

PRM Fan Motor Efficiency	87.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	2.06	Bhp
Total Fan Power	1.75	kW
Fan Ratio Override	4.492	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-09	FC Centrifugal Const Vol	Primary fan	Zone	2,186	0.39	1.75

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-10	
System Type:	Single Zone	
User-entered Total Fan Power	0.11	kW
Design Supply Airflow	594	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	594
Main Exhaust	0.00	594
Room Exhaust	0.00	0
Return	0.00	607
Ventilation	0.00	57

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.56	Bhp
Total Fan Power	0.51	kW
Fan Ratio Override	4.764	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-10	FC Centrifugal Const Vol	Primary fan	Zone	594	0.11	0.51

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-11	
System Type:	Single Zone	
User-entered Total Fan Power	0.09	kW
Design Supply Airflow	493	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	493
Main Exhaust	0.00	493
Room Exhaust	0.00	0
Return	0.00	504
Ventilation	0.00	20
PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.46	Bhp
Total Fan Power	0.42	kW
Fan Ratio Override	4.761	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-11	FC Centrifugal Const Vol	Primary fan	Zone	493	0.09	0.42

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-12	
System Type:	Single Zone	
User-entered Total Fan Power	0.10	kW
Design Supply Airflow	544	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	544
Main Exhaust	0.00	544
Room Exhaust	0.00	0
Return	0.00	554
Ventilation	0.00	15

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.51	Bhp
Total Fan Power	0.46	kW
Fan Ratio Override	4.773	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-12	FC Centrifugal Const Vol	Primary fan	Zone	544	0.10	0.46

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-13	
System Type:	Single Zone	
User-entered Total Fan Power	0.20	kW
Design Supply Airflow	1,139	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	1,139
Main Exhaust	0.00	1,139
Room Exhaust	0.00	0
Return	0.00	1,161
Ventilation	0.00	92
PRM Fan Motor Efficiency	84.00	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	1.07	Bhp
Total Fan Power	0.95	kW
Fan Ratio Override	4.685	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-13	FC Centrifugal Const Vol	Primary fan	Zone	1,139	0.20	0.95

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-14	
System Type:	Single Zone	
User-entered Total Fan Power	0.39	kW
Design Supply Airflow	2,163	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	2,163
Main Exhaust	0.00	2,163
Room Exhaust	0.00	0
Return	0.00	2,226
Ventilation	0.00	305

PRM Fan Motor Efficiency	87.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	2.03	Bhp
Total Fan Power	1.73	kW
Fan Ratio Override	4.490	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-14	FC Centrifugal Const Vol	Primary fan	Zone	2,163	0.39	1.73

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-15	
System Type:	Single Zone	
User-entered Total Fan Power	0.10	kW
Design Supply Airflow	552	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	552
Main Exhaust	0.00	552
Room Exhaust	0.00	0
Return	0.00	566
Ventilation	0.00	31

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.52	Bhp
Total Fan Power	0.47	kW
Fan Ratio Override	4.786	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-15	FC Centrifugal Const Vol	Primary fan	Zone	552	0.10	0.47

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-16	
System Type:	Single Zone	
User-entered Total Fan Power	0.03	kW
Design Supply Airflow	162	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	162
Main Exhaust	0.00	162
Room Exhaust	0.00	0
Return	0.00	167
Ventilation	0.00	20

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.15	Bhp
Total Fan Power	0.14	kW
Fan Ratio Override	4.724	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-16	FC Centrifugal Const Vol	Primary fan	Zone	162	0.03	0.14

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-17	
System Type:	Single Zone	
User-entered Total Fan Power	0.10	kW
Design Supply Airflow	568	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	568
Main Exhaust	0.00	568
Room Exhaust	0.00	0
Return	0.00	585
Ventilation	0.00	76

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.53	Bhp
Total Fan Power	0.48	kW
Fan Ratio Override	4.782	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-17	FC Centrifugal Const Vol	Primary fan	Zone	568	0.10	0.48

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-18	
System Type:	Single Zone	
User-entered Total Fan Power	0.03	kW
Design Supply Airflow	162	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	162
Main Exhaust	0.00	162
Room Exhaust	0.00	0
Return	0.00	162
Ventilation	0.00	64

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.15	Bhp
Total Fan Power	0.14	kW
Fan Ratio Override	4.759	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-18	FC Centrifugal Const Vol	Primary fan	Zone	162	0.03	0.14

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-19	
System Type:	Single Zone	
User-entered Total Fan Power	0.10	kW
Design Supply Airflow	550	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	550
Main Exhaust	0.00	550
Room Exhaust	0.00	0
Return	0.00	564
Ventilation	0.00	35

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.52	Bhp
Total Fan Power	0.47	kW
Fan Ratio Override	4.765	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-19	FC Centrifugal Const Vol	Primary fan	Zone	550	0.10	0.47

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-20	
System Type:	Single Zone	
User-entered Total Fan Power	0.44	kW
Design Supply Airflow	2,449	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	2,449
Main Exhaust	0.00	2,449
Room Exhaust	0.00	0
Return	0.00	2,521
Ventilation	0.00	330
PRM Fan Motor Efficiency	87.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	2.30	Bhp
Total Fan Power	1.96	kW
Fan Ratio Override	4.492	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-20	FC Centrifugal Const Vol	Primary fan	Zone	2,449	0.44	1.96

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-21	
System Type:	Single Zone	
User-entered Total Fan Power	0.06	kW
Design Supply Airflow	333	cfm
PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	333
Main Exhaust	0.00	333
Room Exhaust	0.00	0
Return	0.00	333
Ventilation	0.00	144
PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.31	Bhp
Total Fan Power	0.28	kW
Fan Ratio Override	4.797	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-21	FC Centrifugal Const Vol	Primary fan	Zone	333	0.06	0.28

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-22	
System Type:	Single Zone	
User-entered Total Fan Power	0.11	kW
Design Supply Airflow	623	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	623
Main Exhaust	0.00	623
Room Exhaust	0.00	0
Return	0.00	636
Ventilation	0.00	52

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.59	Bhp
Total Fan Power	0.53	kW
Fan Ratio Override	4.766	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-22	FC Centrifugal Const Vol	Primary fan	Zone	623	0.11	0.53

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-23	
System Type:	Single Zone	
User-entered Total Fan Power	0.04	kW
Design Supply Airflow	211	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	211
Main Exhaust	0.00	211
Room Exhaust	0.00	0
Return	0.00	218
Ventilation	0.00	22

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.20	Bhp
Total Fan Power	0.18	kW
Fan Ratio Override	4.711	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-23	FC Centrifugal Const Vol	Primary fan	Zone	211	0.04	0.18

PRM Fan Power Details

By THORNTON TOMASETTI, INC.

Baseline Alternative: Alternative 2 - ASHRAE Baseline 90.1-07 Climate Zone 6A

Method: 90.1-2007 Performance Rating Method

System Description:	VAV-24	
System Type:	Single Zone	
User-entered Total Fan Power	0.03	kW
Design Supply Airflow	157	cfm

PRM Fan Power Adjustment Factor	Static	
	Adjustment	Airflow
	in. H2O	cfm
Primary	0.00	157
Main Exhaust	0.00	157
Room Exhaust	0.00	0
Return	0.00	157
Ventilation	0.00	43

PRM Fan Motor Efficiency	82.50	%
PRM Fan Power Adjustment BHP	0.00	Bhp
Calculated System BHP	0.15	Bhp
Total Fan Power	0.13	kW
Fan Ratio Override	4.786	

Zone Description	Fan Name	Fan Type	Fan Level	Design Airflow (cfm)	Original F.L. Rate (kW)	PRM Fan Power (kW)
VAV-24	FC Centrifugal Const Vol	Primary fan	Zone	157	0.03	0.13

Entered Values

TRACE® 700 version 6.3.1

By THORNTON TOMASETTI, INC.

Project Name:

Dataset Name: C:\Users\jbeaumont\Documents\TRACE PROJECTS\IP14009\REVIEW\IP14009E150610.TRC

Location:

Building Owner:

Program User:

Company:

Comments: WING_TEMPLATE_PROCESSING

Cooling Design Period:	January thru December	Location:	BRUNSWICK NAS, Maine
Peak Hour Override:	0	Summer Design Dry Bulb:	83.30 °F
Daylight Savings Period:	April Thru October	Summer Design Wet Bulb:	68.80 °F
Summer Period:		Winter Design Dry Bulb:	-1.90 °F
Cooling Methodology:	RTS (Heat Balance)	Summer Clearness Number:	1.00
Heating Methodology:	CLTD-CLF (ASHRAE-TFM)	Winter Clearness Number:	1.00
Infiltration Methodology:	Vary with wind speed	Summer Ground Reflectance:	0.20
Outside Film Methodology:	Vary with wind speed	Winter Ground Reflectance:	0.20
Terrain Methodology:	Urban, industrial, or forest area	Carbon Dioxide Level:	400 ppm
Room Circ Rate:	Medium	Force VAV Min => Nominal Ventilation at Design:	Yes
Wall Load To Plenum:	YES	Allow Energy Recovery/Transfer at Design:	No
Building Orientation:	65 degrees from north	Retest Design Peaks:	Yes
Simulation Hours:	Full year	Calculate Building Block Loads:	No
Calendar Code:	Standard (1978)		
Energy Simulation Period:	January thru December	Close ventilation dampers during unoccupied hours:	Yes

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 001 - STAIR 2

Zone Description: BASEBOARD

System Description: BASEBOARD

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 203 ft ² Flr-Flr Height: 40.5 ft Plenum Height: 0.0 ft Height Above Flr: -11 ft Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 0 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: Neutral, Poor Const. Infil Value: 1.00 air changes/hr Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm Neutral, Poor Const. 1.00 air changes/hr Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F					
Roof - 1	188 ft ²	0	90	P14009-ROOF B	0.0234	0.55									
N1	492 ft ²	0	0	P14009-WALL	0.0520	0.90									
B2				Window			P14009-WINDOW	94	0.43	0.35	Overhang - None	None	0.00		
SPN- 2				Door			Standard Door	44	0.00	0.20	Overhang - None	None	0.00		
GLZ DOORS				Window			P14009-WINDOW	72	0.43	0.35	Overhang - None	None	0.00		
N2	294 ft ²	0	0	P14009-WALL	0.0520	0.90									
B2				Window			P14009-WINDOW	55	0.43	0.35	Overhang - None	None	0.00		
SPN - 2				Door			Standard Door	26	0.00	0.20	Overhang - None	None	0.00		
A2				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00		
Partition - 1	373 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000	
Partition - 2	102 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000	
Partition - 3	102 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000	
Floor - 1															

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 138-SERVER

Zone Description: HP-07

System Description: HP-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 135 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 74.0 °F / 74.0 °F Design Htg DB / Drift Point: 70.0 °F / 70.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1,000 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: 760.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
									U Value Btu/h·ft ² ·°F	U Value Btu/h·ft ² ·°F								
Misc Load 1	20.000 W/sq ft		Misc - Low rise office			Electricity									100	100	0	60.00

Room Description: 002 - MECHANICAL ROOM (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 1,015 ft ² Flr-Flr Height: 11.3 ft Plenum Height: 0.0 ft Height Above Flr: -11 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 1,000 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
									U Value Btu/h·ft ² ·°F	U Value Btu/h·ft ² ·°F							
Partition - 1	362 ft ²		8* HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	
Partition - 2	362 ft ²		8* HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	
Partition - 3	396 ft ²		8* HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 108-TRASH/RECYCLE (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 48 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.3 W/sq ft Ballast Factor: 1.0	<table style="width: 100%;"> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> <tr> <td>Vent Type: None</td> <td>None</td> </tr> <tr> <td>Vent Value: 0.00 cfm</td> <td>0.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </table>	Cooling	Heating	Vent Type: None	None	Vent Value: 0.00 cfm	0.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: None	None																											
Vent Value: 0.00 cfm	0.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																											
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/		Const Type /	U Value	Glass				External	Internal	Adj	Pct	Pct	Pct	Rad	
	Amount	Dir			Tilt	Schedule	Alpha	Type /								Area
				Btu/h-ft ² ·°F		Energy Type	ft ²	Coef	Btu/h-ft ² ·°F			Grnd	Cool	Heat	Perm	Loss

Room Description: 109-STORAGE (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 42 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.9 W/sq ft Ballast Factor: 1.0	<table style="width: 100%;"> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> <tr> <td>Vent Type: None</td> <td>None</td> </tr> <tr> <td>Vent Value: 0.00 cfm</td> <td>0.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </table>	Cooling	Heating	Vent Type: None	None	Vent Value: 0.00 cfm	0.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: None	None																											
Vent Value: 0.00 cfm	0.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																											
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/		Const Type /	U Value	Glass				External	Internal	Adj	Pct	Pct	Pct	Rad	
	Amount	Dir			Tilt	Schedule	Alpha	Type /								Area
				Btu/h-ft ² ·°F		Energy Type	ft ²	Coef	Btu/h-ft ² ·°F			Grnd	Cool	Heat	Perm	Loss

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 127-STORAGE (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 60 ft² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft²·°F/Btu Is there Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border: none;"> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> <tr> <td>Vent Type: None</td> <td>None</td> </tr> <tr> <td>Vent Value: 0.00 cfm</td> <td>0.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </table>	Cooling	Heating	Vent Type: None	None	Vent Value: 0.00 cfm	0.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: None	None																											
Vent Value: 0.00 cfm	0.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																											
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/		Const Type /	U Value	Alpha	Type /	Area	Shade	Glass		External	Internal	Adj	Pct	Pct	Pct	Rad
	Amount	Dir							Tilt	Schedule							

Room Description: 129-STORAGE (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 82 ft² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft²·°F/Btu Is there Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border: none;"> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> <tr> <td>Vent Type: None</td> <td>None</td> </tr> <tr> <td>Vent Value: 0.00 cfm</td> <td>0.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </table>	Cooling	Heating	Vent Type: None	None	Vent Value: 0.00 cfm	0.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: None	None																											
Vent Value: 0.00 cfm	0.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																											
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/		Const Type /	U Value	Alpha	Type /	Area	Shade	Glass		External	Internal	Adj	Pct	Pct	Pct	Rad
	Amount	Dir							Tilt	Schedule							

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 222-CLOSET (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 27 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.4 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Pct Frc/ Loss Coef	Rad	
									U Value Btu/h-ft ² ·°F	External Shading									
Roof - 1	27 ft ²	0	90 P14009-ROOF B	0.0234	0.55		0		Overhang - None		None								

Room Description: 247-JANITOR (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 45 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 5.7 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 143 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Pct Frc/ Loss Coef	Rad	
									U Value Btu/h-ft ² ·°F	External Shading									
Roof - 1	45 ft ²	0	90 P14009-ROOF B	0.0234	0.55		0		Overhang - None		None								

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 128-A-BOARDROOM

Zone Description: VAV-01

System Description: VAV-01

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 670 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 25 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 2,000.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating (Area-based) Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
W	328 ft ²	270	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	49	0.43	0.35	Overhang - None	None	0.00			
D1				Window			P14009-WINDOW	65	0.43	0.35	Overhang - None	None	0.00			
SPN-D1				Door			Standard Door	65	0.00	0.20	Overhang - None	None	0.00			
N	425 ft ²	0	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	49	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
F1				Window			P14009-WINDOW	37	0.43	0.35	Overhang - None	None	0.00			
SPN-F2				Window			P14009-WINDOW	26	0.43	0.35	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																51 0.55

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 128-B-BOARDROOM

Zone Description: VAV-02

System Description: VAV-02

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 803 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 25 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 2,000.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
N	428 ft ²	0	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	49	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
F1				Window			P14009-WINDOW	37	0.43	0.35	Overhang - None	None	0.00			
SPN-F2				Door			Standard Door	26	0.00	0.20	Overhang - None	None	0.00			
E	144 ft ²	90	0	P14009-WALL	0.0520	0.90										
E1				Window			P14009-WINDOW	77	0.43	0.35	Overhang - None	None	0.00			
SPN				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																38 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 112-126 - OPEN OFFICE

Zone Description: VAV-03

System Description: VAV-03

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 1,615 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 8 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 1,800.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F					
S	417 ft ²	180	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00		
B1				Window			P14009-WINDOW	94	0.43	0.35	Overhang - None	None	0.00		
SPN-B1				Door			Standard Door	94	0.00	0.20	Overhang - None	None	0.00		
W	574 ft ²	270	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	122	0.43	0.35	Overhang - None	None	0.00		
N	30 ft ²	0	0	P14009-WALL	0.0520	0.90									
S2	30 ft ²	180	0	P14009-WALL	0.0520	0.90									
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity						100	100	0 60.00
Floor - 1															71 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 118-CONFERENCE ROOM

Zone Description: VAV-04

System Description: VAV-04

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 140 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 300.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)	<u>Heating (Area-based)</u> Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef		
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading	Internal Shading
S	243 ft ²	180	0	P14009-WALL	0.0520	0.90											
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00				
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00				
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00				
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00				
W	149 ft ²	270	0	P14009-WALL	0.0520	0.90											
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00				
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00				
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00				
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0	60.00
Floor - 1																26	0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 100-VESTIBULE

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 98 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 0 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.3 W/sq ft Ballast Factor: 1.0	Cooling (Peop-based) Vent Type: Corridors Vent Value: 0.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: Neutral, Loose Const. Infil Value: 2.50 air changes/hr Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 75.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	Heating (Area-based) Corridors 0.06 cfm/sq ft Neutral, Loose Const. 2.50 air changes/hr Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F					
Roof - 1	98 ft ²	0	90	P14009-ROOF B	0.0234	0.55									
S	164 ft ²	180	0	P14009-WALL	0.0520	0.90									
J1				Window			P14009-WINDOW	97	0.43	0.35	Overhang - None	None	0.00		
SPN-J1				Door			Standard Door	15	0.00	0.20	Overhang - None	None	0.00		
W	149 ft ²	270	0	P14009-WALL	0.0520	0.90									
G1				Window			P14009-WINDOW	63	0.43	0.35	Overhang - None	None	0.00		
SPN-G1				Door			Standard Door	34	0.00	0.20	Overhang - None	None	0.00		
Floor - 1															21 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 101-LOBBY

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 750 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: Reception Area # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.8 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Reception areas Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 600.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Reception areas 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F					
S	432 ft ²	180	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	73	0.43	0.35	Overhang - None	None	0.00		
K1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00		
SPN-K1				Window			P14009-WINDOW	14	0.43	0.35	Overhang - None	None	0.00		
SPN				Window			P14009-WINDOW	35	0.43	0.35	Overhang - None	None	0.00		
Misc Load 1	150.000 W			Misc - Low rise office			Electricity						100	100	0 60.00
Misc Load 2	150.000 W			Misc - Low rise office			Electricity						100	100	0 60.00
Floor - 1															29 0.55

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 107-SITTING

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 500 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: Reception Area # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.4 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Reception areas Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 600.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) <u>Std 62.1-2004</u> Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Reception areas 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							U Value Btu/h-ft ² ·°F	Shade Coef	U Value Btu/h-ft ² ·°F							

Room Description: 130-STAFF LOUNGE

Zone Description: VAV-06

System Description: VAV-06

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 545 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 10 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Break Rooms Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 400.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) <u>Std 62.1-2004</u> Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Break Rooms 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							U Value Btu/h-ft ² ·°F	Shade Coef	U Value Btu/h-ft ² ·°F							

N	417 ft ²	0	0 P14009-WALL	0.0520	0.90											
A1			Window			P14009-WINDOW	73	0.43	0.35	Overhang - None	None	0.00				
W	45 ft ²	270	0 P14009-WALL	0.0520	0.90											
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity							100	100	0	60.00
Floor - 1																31 0.55

ENTERED VALUES
ROOM BY ROOM
By THORNTON TOMASETTI, INC.

Room Description: 105-WOMENS TOILET

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
<p>Floor Area: 165 ft² Flr-Flr Height: 14.9 ft Plenum Height: 5.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft²·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned</p>	<p>People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0</p>	<p><u>Cooling</u> Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 85.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)</p> <p><u>Heating</u> None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated</p>

Description	Area/		Const Type /	U Value		Type /	Glass		External	Internal	Adj	Pct	Pct	Pct	Rad
	Amount	Dir		Tilt	Schedule		Btu/h-ft²·°F	Alpha			Area	Shade	U Value	Shading	Temp/
							ft²	Coef	Btu/h-ft²·°F		Grnd	Cool	Heat	Perm	Loss

Room Description: 106-MENS TOILET

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
<p>Floor Area: 156 ft² Flr-Flr Height: 14.9 ft Plenum Height: 5.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft²·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned</p>	<p>People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0</p>	<p><u>Cooling</u> Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 85.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)</p> <p><u>Heating</u> None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated</p>

Description	Area/		Const Type /	U Value		Type /	Glass		External	Internal	Adj	Pct	Pct	Pct	Rad
	Amount	Dir		Tilt	Schedule		Btu/h-ft²·°F	Alpha			Area	Shade	U Value	Shading	Temp/
							ft²	Coef	Btu/h-ft²·°F		Grnd	Cool	Heat	Perm	Loss

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 131-133-CORRIDOR

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 310 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed florescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling (Peop-based) Vent Type: Corridors Vent Value: 0.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 115.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	Heating (Area-based) Corridors 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
									U Value Btu/h·ft ² ·°F	Alpha							

Room Description: 136-TECHNICAL SERVICES

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 357 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed florescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling (Peop-based) Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 590.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	Heating (Area-based) Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef			
									U Value Btu/h·ft ² ·°F	Alpha										
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity											100	100	0	60.00

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 137-TECH SERVICES OFFICE

Zone Description: VAV-07

System Description: VAV-07

<u>GENERAL INFORMATION</u>	<u>PEOPLE</u>	<u>AIRFLOW INFORMATION</u>																																		
Floor Area: 103 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;"><u>Cooling (Peop-based)</u></th> <th style="text-align: left;"><u>Heating (Area-based)</u></th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 235.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td colspan="2">Er: Default based on system type</td> </tr> </tbody> </table>	<u>Cooling (Peop-based)</u>	<u>Heating (Area-based)</u>	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 235.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
<u>Cooling (Peop-based)</u>	<u>Heating (Area-based)</u>																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 235.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² -°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
							Temp/ Grnd Ref	Sen/ Cool Tmp	Rm/ Heat Tmp			Ret/ Perm Len	Frc/ Loss Coef			
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity							100	100		0 60.00

Room Description: 140-WORKROOM

Zone Description: VAV-07

System Description: VAV-07

<u>GENERAL INFORMATION</u>	<u>PEOPLE</u>	<u>AIRFLOW INFORMATION</u>																																		
Floor Area: 165 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.7 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;"><u>Cooling (Peop-based)</u></th> <th style="text-align: left;"><u>Heating (Area-based)</u></th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 160.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td colspan="2">Er: Default based on system type</td> </tr> </tbody> </table>	<u>Cooling (Peop-based)</u>	<u>Heating (Area-based)</u>	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 160.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
<u>Cooling (Peop-based)</u>	<u>Heating (Area-based)</u>																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 160.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² -°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
							Temp/ Grnd Ref	Sen/ Cool Tmp	Rm/ Heat Tmp			Ret/ Perm Len	Frc/ Loss Coef			
COPIERS (2X)	800.000 W		Misc - Low rise office			Electricity							100	100		0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 144-CONFERENCE ROOM

Zone Description: VAV-08

System Description: VAV-08

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 132 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 400.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating (Area-based) Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated To be calculated	<u>Std 62.1-2004</u> Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
N	142 ft ²	0	0	P14009-WALL	0.0520	0.90										
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
E	238 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																26 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 103-MAIL

Zone Description: VAV-09

System Description: VAV-09

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 130 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.3 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 100.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F					
S	112 ft ²	180	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00		
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity						100	100	0 60.00
Floor - 1															8 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 147-LOANS SERV OPEN OFFICE

Zone Description: VAV-09

System Description: VAV-09

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 2,656 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 12 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 2,250.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)	<u>Heating (Area-based)</u> Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
N	365 ft ²	0	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	98	0.43	0.35	Overhang - None	None	0.00			
E1	50 ft ²	90	0	P14009-WALL	0.0520	0.90										
E2	621 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	146	0.43	0.35	Overhang - None	None	0.00			
S	779 ft ²	180	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	122	0.43	0.35	Overhang - None	None	0.00			
B1				Window			P14009-WINDOW	94	0.43	0.35	Overhang - None	None	0.00			
SPN-B1				Door			Standard Door	44	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																122 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 149-CONFERENCE ROOM

Zone Description: VAV-10

System Description: VAV-10

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 121 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 420.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)	<u>Heating (Area-based)</u> Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
E	214 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
S	144 ft ²	180	0	P14009-WALL	0.0520	0.90										
C1				Window			P14009-WINDOW	62	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	16	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	35	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																24 0.55

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 219-CONFERENCE ROOM

Zone Description: VAV-11

System Description: VAV-11

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 84 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.4 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 200.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F					
Roof - 1	84 ft ²	0	90	P14009-ROOF B	0.0234	0.55									
W	149 ft ²	270	0	P14009-WALL	0.0520	0.90				Overhang - None	None				
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00		
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00		
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00		
N	142 ft ²	0	0	P14009-WALL	0.0520	0.90									
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00		
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00		
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00		
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity						100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 220-CONFERENCE ROOM

Zone Description: VAV-12

System Description: VAV-12

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 69 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 150.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating (Area-based) Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated To be calculated	Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading
Roof - 1	69 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
N	123 ft ²	0	0	P14009-WALL	0.0520	0.90				Overhang - None	None					
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
E	135 ft ²	90	0	P14009-WALL	0.0520	0.90										
E1				Window			P14009-WINDOW	81	0.43	0.35	Overhang - None	None	0.00			
SPN-E1				Window			P14009-WINDOW	18	0.43	0.35	Overhang - None	None	0.00			
SPN				Window			P14009-WINDOW	35	0.43	0.35	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 201-LOBBY

Zone Description: VAV-13

System Description: VAV-13

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 1,200 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: Reception Area # of People: 5 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Reception areas</td> <td>Reception areas</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 900.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Reception areas	Reception areas	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 900.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Reception areas	Reception areas																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 900.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	1,200 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
S	412 ft ²	180	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	73	0.43	0.35	Overhang - None	None	0.00			
K1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-K1				Window			P14009-WINDOW	16	0.43	0.35	Overhang - None	None	0.00			
SPN				Window			P14009-WINDOW	32	0.43	0.35	Overhang - None	None	0.00			
W	152 ft ²	270	0	P14009-WALL	0.0520	0.90										
H1				Window			P14009-WINDOW	85	0.43	0.35	Overhang - None	None	0.00			
SPN-H1				Door			Standard Door	66	0.00	0.20	Overhang - None	None	0.00			

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 221-CAP MNGMT OPEN OFFICE

Zone Description: VAV-14

System Description: VAV-14

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 3,214 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 22 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 2,990.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 2,990.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 2,990.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F					
Roof - 1	3,214 ft ²	0	90	P14009-ROOF B	0.0234	0.55									
S1	334 ft ²	180	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00		
B1				Window			P14009-WINDOW	83	0.43	0.35	Overhang - None	None	0.00		
SPN-B1				Door			Standard Door	39	0.00	0.20	Overhang - None	None	0.00		
W	720 ft ²	270	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	195	0.43	0.35	Overhang - None	None	0.00		
S2	28 ft ²	180	0	P14009-WALL	0.0520	0.90									
N2	28 ft ²	0	0	P14009-WALL	0.0520	0.90									
N1	549 ft ²	0	0	P14009-WALL	0.0520	0.90									
A1				Window			P14009-WINDOW	98	0.43	0.35	Overhang - None	None	0.00		
F1				Window			P14009-WINDOW	72	0.43	0.35	Overhang - None	None	0.00		
SPN-F1				Door			Standard Door	52	0.00	0.20	Overhang - None	None	0.00		
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity						100	100	0 60.00
COPIER	400.000 W			Misc - Low rise office			Electricity						100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 210-CONFERENCE ROOM

Zone Description: VAV-15

System Description: VAV-15

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 134 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 4 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 300.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 300.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Conference/ meeting	Conference/ meeting																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 300.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading
Roof - 1	134 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
S	227 ft ²	180	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
W	142 ft ²	270	0	P14009-WALL	0.0520	0.90										
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 207-CONFERENCE ROOM

Zone Description: VAV-16

System Description: VAV-16

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 94 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.8 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 200.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 200.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Conference/ meeting	Conference/ meeting																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 200.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	94 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
S	135 ft ²	180	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity						100	100	0	60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 223-CONFERENCE ROOM

Zone Description: VAV-17

System Description: VAV-17

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 478 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 15 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling (Peop-based) Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 560.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	Heating (Area-based) Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	478 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
N	398 ft ²	0	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	98	0.43	0.35	Overhang - None	None	0.00			
W	43 ft ²	270	0	P14009-WALL	0.0520	0.90										
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 225-CAPITAL VENTURE OPEN OFFICE

Zone Description: VAV-18

System Description: VAV-18

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																			
Floor Area: 400 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Fir: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 470.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 470.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type		
Cooling (Peop-based)	Heating (Area-based)																																				
Vent Type: Office space	Office space																																				
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																				
Vent Schedule: Vent - Low rise office																																					
Infil Type: IRS STANDARD	IRS STANDARD																																				
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																				
Infil Schedule: Available (100%)																																					
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																				
Vav Sched: Available (100%)																																					
Supply: 470.00 cfm	To be calculated																																				
Aux Supply: To be calculated	To be calculated																																				
Room Exhaust:																																					
Rm Exh Sched: Available (100%)																																					
Std 62.1-2004																																					
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																				
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																				
Er: Default based on system type																																					

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	400 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity			Overhang - None	None			100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 232-CONFERENCE ROOM

Zone Description: VAV-19

System Description: VAV-19

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																
Floor Area: 132 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Cooling (Peop-based)</th> <th style="text-align: left;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 260.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table> <p style="text-align: center;">Std 62.1-2004</p> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 260.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																	
Vent Type: Conference/ meeting	Conference/ meeting																																	
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																	
Vent Schedule: Vent - Low rise office																																		
Infil Type: IRS STANDARD	IRS STANDARD																																	
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																	
Infil Schedule: Available (100%)																																		
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																	
Vav Sched: Available (100%)																																		
Supply: 260.00 cfm	To be calculated																																	
Aux Supply: To be calculated	To be calculated																																	
Room Exhaust:																																		
Rm Exh Sched: Available (100%)																																		
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																	
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																	
Er: Default based on system type																																		

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading
Roof - 1	132 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
N	135 ft ²	0	0	P14009-WALL	0.0520	0.90										
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
E	227 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 237-LENDING OPEN OFFICE

Zone Description: VAV-20

System Description: VAV-20

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 3,066 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 16 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Cooling (Peop-based)</th> <th style="text-align: left;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 2,430.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 2,430.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 2,430.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	3,066 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
N	345 ft ²	0	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	98	0.43	0.35	Overhang - None	None	0.00			
E2	47 ft ²	90	0	P14009-WALL	0.0520	0.90										
E1	589 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	146	0.43	0.35	Overhang - None	None	0.00			
S	918 ft ²	180	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	171	0.43	0.35	Overhang - None	None	0.00			
B1				Window			P14009-WINDOW	83	0.43	0.35	Overhang - None	None	0.00			
SPN-B1				Door			Standard Door	39	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 224-KITCHENETTE

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 332 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.4 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Break Rooms Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 540.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Break Rooms 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							
Roof - 1	332 ft ²	0	90 P14009-ROOF B	0.0234	0.55					Overhang - None	None					
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity							100	100	0	60.00

Room Description: 228-CORRIDOR

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 207 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Corridors Vent Value: 0.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 150.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Corridors 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							
Roof - 1	207 ft ²	0	90 P14009-ROOF B	0.0234	0.55					Overhang - None	None					

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 248-WORK AREA

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 186 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 5.7 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 2 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Cooling (Peop-based)</th> <th style="width: 50%; text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 200.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 200.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 200.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Shade Coef	U Value Btu/h-ft ² ·°F	Area ft ²							
COPIER	400.000 W		Misc - Low rise office			Electricity								100	100	0 60.00

Room Description: 249-MENS TOILET

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 165 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 5.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Cooling</th> <th style="width: 50%; text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: None</td> <td>None</td> </tr> <tr> <td>Vent Value: 0.00 cfm</td> <td>0.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 85.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: None	None	Vent Value: 0.00 cfm	0.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 85.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: None	None																											
Vent Value: 0.00 cfm	0.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																											
Vav Sched: Available (100%)																												
Supply: 85.00 cfm	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Shade Coef	U Value Btu/h-ft ² ·°F	Area ft ²							
Roof - 1	165 ft ²	0	90 P14009-ROOF B	0.0234	0.55					Overhang - None	None					

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 240-CONFERENCE ROOM

Zone Description: VAV-22

System Description: VAV-22

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																
Floor Area: 115 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling (Peop-based)</th> <th style="text-align: center;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 380.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table> <p style="text-align: center;">Std 62.1-2004</p> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 380.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																	
Vent Type: Conference/ meeting	Conference/ meeting																																	
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																	
Vent Schedule: Vent - Low rise office																																		
Infil Type: IRS STANDARD	IRS STANDARD																																	
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																	
Infil Schedule: Available (100%)																																		
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																	
Vav Sched: Available (100%)																																		
Supply: 380.00 cfm	To be calculated																																	
Aux Supply: To be calculated	To be calculated																																	
Room Exhaust:																																		
Rm Exh Sched: Available (100%)																																		
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																	
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																	
Er: Default based on system type																																		

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	115 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
E	206 ft ²	90	0	P14009-WALL	0.0520	0.90										
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Window			P14009-WINDOW	18	0.43	0.35	Overhang - None	None	0.00			
SPN				Window			P14009-WINDOW	33	0.43	0.35	Overhang - None	None	0.00			
S	137 ft ²	180	0	P14009-WALL	0.0520	0.90										
C1				Window			P14009-WINDOW	68	0.43	0.35	Overhang - None	None	0.00			
SPN-C1				Door			Standard Door	18	0.00	0.20	Overhang - None	None	0.00			
SPN				Door			Standard Door	33	0.00	0.20	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 226-CCVI OFFICE

Zone Description: VAV-23

System Description: VAV-23

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																																		
Floor Area: 116 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.6 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Cooling (Peop-based)</th> <th style="text-align: left;">Heating (Area-based)</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 5.00 cfm/person</td> <td>0.06 cfm/sq ft</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow: Min: 30.00 % Clg Airflow</td> <td>Max: 60.00 % Clg Airflow</td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: 165.00 cfm</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> <tr> <td colspan="2" style="text-align: center;">Std 62.1-2004</td> </tr> <tr> <td>Cooling Ez: Ceiling clg supply, ceiling return</td> <td style="text-align: right;">100 %</td> </tr> <tr> <td>Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return</td> <td style="text-align: right;">80 %</td> </tr> <tr> <td>Er: Default based on system type</td> <td></td> </tr> </tbody> </table>	Cooling (Peop-based)	Heating (Area-based)	Vent Type: Office space	Office space	Vent Value: 5.00 cfm/person	0.06 cfm/sq ft	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow	Vav Sched: Available (100%)		Supply: 165.00 cfm	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)		Std 62.1-2004		Cooling Ez: Ceiling clg supply, ceiling return	100 %	Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %	Er: Default based on system type	
Cooling (Peop-based)	Heating (Area-based)																																			
Vent Type: Office space	Office space																																			
Vent Value: 5.00 cfm/person	0.06 cfm/sq ft																																			
Vent Schedule: Vent - Low rise office																																				
Infil Type: IRS STANDARD	IRS STANDARD																																			
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																																			
Infil Schedule: Available (100%)																																				
Vav Airflow: Min: 30.00 % Clg Airflow	Max: 60.00 % Clg Airflow																																			
Vav Sched: Available (100%)																																				
Supply: 165.00 cfm	To be calculated																																			
Aux Supply: To be calculated	To be calculated																																			
Room Exhaust:																																				
Rm Exh Sched: Available (100%)																																				
Std 62.1-2004																																				
Cooling Ez: Ceiling clg supply, ceiling return	100 %																																			
Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return	80 %																																			
Er: Default based on system type																																				

Description	Area/Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/Grnd Refl	Pct Sen/Cool Tmp	Pct Rm/Heat Tmp	Pct Ret/Perm Len	Rad Frc/Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F						External Shading
Roof - 1	116 ft ²	0	90	P14009-ROOF B	0.0234	0.55										
N	185 ft ²	0	0	P14009-WALL	0.0520	0.90										
B1				Window			P14009-WINDOW	28	0.43	0.35	Overhang - None	None	0.00			
SPN-B1				Door			Standard Door	13	0.00	0.20	Overhang - None	None	0.00			
A1				Window			P14009-WINDOW	24	0.43	0.35	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 122-CONFERENCE ROOM

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 100 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 5.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: Conference Room # of People: 1 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.7 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Conference/ meeting Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 90.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Conference/ meeting 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Pct Frc/ Loss Coef
							Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F							
Misc Load 1	0.500 W/sq ft		Misc - Low rise office			Electricity							100	100	0	60.00

Room Description: 123-OFFICE

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 205 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.7 W/sq ft Ballast Factor: 1.0	<u>Cooling (Peop-based)</u> Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 190.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	<u>Heating (Area-based)</u> Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Pct Frc/ Loss Coef
							Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F							
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity							100	100	0	60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 124-OFFICE

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION	
Floor Area: 158 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling (Peop-based) Vent Type: Office space Vent Value: 5.00 cfm/person Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Min: 30.00 % Clg Airflow Vav Sched: Available (100%) Supply: 145.00 cfm Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Std 62.1-2004 Cooling Ez: Ceiling clg supply, ceiling return 100 % Heating Ez: Ceiling supply > Trm+15°F(8°C), ceiling return 80 % Er: Default based on system type	Heating (Area-based) Office space 0.06 cfm/sq ft IRS STANDARD 0.04 cfm/sq ft of wall Max: 60.00 % Clg Airflow To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			Adj Temp/ Refl	Pct Sen/ Cool	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
								Shade Coef	U Value Btu/h·ft ² ·°F	External Shading						Internal Shading
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 001 - STAIR 2

Zone Description: BASEBOARD

System Description: BASEBOARD

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 203 ft ² Flr-Flr Height: 40.5 ft Plenum Height: 0.0 ft Height Above Flr: -11 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 0 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.8 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Corridors Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: Neutral, Poor Const. Infil Value: 1.00 air changes/hr Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Corridors 0.00 cfm Neutral, Poor Const. 1.00 air changes/hr To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F						External Shading
Roof - 1	188 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
N1	492 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
B2				Window			90.1 Window Zone 4-6	94	0.46	0.55	Overhang - None	None	0.00			
SPN- 2				Door			90.1-07 Min Swinging	44	0.00	0.70	Overhang - None	None	0.00			
GLZ DOORS				Window			90.1 Window Zone 4-6	72	0.46	0.55	Overhang - None	None	0.00			
N2	294 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
B2				Window			90.1 Window Zone 4-6	55	0.46	0.55	Overhang - None	None	0.00			
SPN - 2				Door			90.1-07 Min Swinging	26	0.00	0.70	Overhang - None	None	0.00			
A2				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
Partition - 1	373 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000		
Partition - 2	102 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000		
Partition - 3	102 ft ²			8* HW Conc, 2* EPS	0.0964								Ground	0,00010,000		
Floor - 1																

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 138-SERVER

Zone Description: HP-07

System Description: HP-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 135 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 74.0 °F / 74.0 °F Design Htg DB / Drift Point: 70.0 °F / 70.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1,000 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.5 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
									U Value Btu/h-ft ² ·°F	U Value Btu/h-ft ² ·°F								
Misc Load 1	20.000 W/sq ft		Misc - Low rise office			Electricity									100	100	0	60.00

Room Description: 002 - MECHANICAL ROOM (UNCOND)

Zone Description: UNCONDITIONED

System Description: UNCONDITIONED

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 1,015 ft ² Flr-Flr Height: 11.3 ft Plenum Height: 0.0 ft Height Above Flr: -11 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:None Room Multiplier: 1 CO2 Sensor Location:None Room Type:Unconditioned	People Type: General Office Space # of People: 1,000 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.5 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating None 0.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
									U Value Btu/h-ft ² ·°F	U Value Btu/h-ft ² ·°F							
Partition - 1	362 ft ²		8" HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	
Partition - 2	362 ft ²		8" HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	
Partition - 3	396 ft ²		8" HW Conc, 2* EPS	0.0964									Ground		0,000	10,000	

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 128-A-BOARDROOM

Zone Description: VAV-01

System Description: VAV-01

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 670 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 25 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 204.00 cfm</td> <td>204.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 204.00 cfm	204.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Conference/ meeting	Conference/ meeting																											
Vent Value: 204.00 cfm	204.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
W	328 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	49	0.46	0.55	Overhang - None	None	0.00			
D1				Window			90.1 Window Zone 4-6	65	0.46	0.55	Overhang - None	None	0.00			
SPN-D1				Door			90.1-07 Min Swinging	65	0.00	0.70	Overhang - None	None	0.00			
N	425 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	49	0.46	0.55	Overhang - None	None	0.00			
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
F1				Window			90.1 Window Zone 4-6	37	0.46	0.55	Overhang - None	None	0.00			
SPN-F2				Window			90.1 Window Zone 4-6	26	0.46	0.55	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																51 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 112-126 - OPEN OFFICE

Zone Description: VAV-03

System Description: VAV-03

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 1,615 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 8 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 184.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 184.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F	External Shading					
S	417 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
B1				Window			90.1 Window Zone 4-6	94	0.46	0.55	Overhang - None	None	0.00			
SPN-B1				Door			90.1-07 Min Swinging	94	0.00	0.70	Overhang - None	None	0.00			
W	574 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	122	0.46	0.55	Overhang - None	None	0.00			
N	30 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
S2	30 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																71 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 118-CONFERENCE ROOM

Zone Description: VAV-04

System Description: VAV-04

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 140 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Cooling</th> <th style="width: 50%; text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 31.00 cfm</td> <td>31.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 31.00 cfm	31.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Conference/ meeting	Conference/ meeting																											
Vent Value: 31.00 cfm	31.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F	External Shading					
S	243 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
W	149 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																26 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 100-VESTIBULE

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 98 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 55.0 °F / 55.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 0 sq ft/person People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Corridors Vent Value: 8.00 cfm Vent Schedule: Vent - Low rise office Infil Type: Neutral, Loose Const. Infil Value: 2.50 air changes/hr Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Corridors 8.00 cfm Neutral, Loose Const. 2.50 air changes/hr To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading						Internal Shading
Roof - 1	98 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70											
S	164 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90											
J1				Window			90.1	0.46	0.55	Overhang - None	None	0.00					
SPN-J1				Door			90.1-07	0.00	0.70	Overhang - None	None	0.00					
W	149 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90											
G1				Window			90.1	0.46	0.55	Overhang - None	None	0.00					
SPN-G1				Door			90.1-07	0.00	0.70	Overhang - None	None	0.00					
Floor - 1																	21 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 101-LOBBY

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 750 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: Reception Area # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Reception areas Vent Value: 61.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Reception areas 61.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Tmp	Pct Rm/ Tmp	Pct Ret/ Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F					
S	432 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90									
A1				Window			90.1 Window Zone 4-6	73	0.46	0.55	Overhang - None	None	0.00		
K1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00		
SPN-K1				Window			90.1 Window Zone 4-6	14	0.46	0.55	Overhang - None	None	0.00		
SPN				Window			90.1 Window Zone 4-6	35	0.46	0.55	Overhang - None	None	0.00		
Misc Load 1	150.000 W			Misc - Low rise office			Electricity						100	100	0 60.00
Misc Load 2	150.000 W			Misc - Low rise office			Electricity						100	100	0 60.00
Floor - 1															29 0.73

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 107-SITTING

Zone Description: VAV-05

System Description: VAV-05

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 500 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: Reception Area # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Reception areas Vent Value: 61.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating Reception areas 61.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
									U Value Btu/h-ft ² ·°F	Internal Shading							

Room Description: 130-STAFF LOUNGE

Zone Description: VAV-06

System Description: VAV-06

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 545 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 10 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.2 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Break Rooms Vent Value: 54.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating Break Rooms 54.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
									U Value Btu/h-ft ² ·°F	Internal Shading							

N	417 ft ²	0	0 90.1-07 Min Wall Nonres	0.0646	0.90												
A1			Window			90.1 Window Zone 4-6	73	0.46	0.55	Overhang - None	None	0.00					
W	45 ft ²	270	0 90.1-07 Min Wall Nonres	0.0646	0.90												
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity								100	100	0	60.00
Floor - 1																	31 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 105-WOMENS TOILET

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 165 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 5.9 ft Height Above Flr: Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.9 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Cooling</th> <th style="width: 50%; text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Rest Room</td> <td>Rest Room</td> </tr> <tr> <td>Vent Value: 12.00 cfm</td> <td>12.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Rest Room	Rest Room	Vent Value: 12.00 cfm	12.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Rest Room	Rest Room																											
Vent Value: 12.00 cfm	12.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
								Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							

Room Description: 106-MENS TOILET

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 156 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 5.9 ft Height Above Flr: Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.9 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Cooling</th> <th style="width: 50%; text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Rest Room</td> <td>Rest Room</td> </tr> <tr> <td>Vent Value: 12.00 cfm</td> <td>12.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Rest Room	Rest Room	Vent Value: 12.00 cfm	12.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Rest Room	Rest Room																											
Vent Value: 12.00 cfm	12.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
								Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 131-133-CORRIDOR

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 310 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Corridors Vent Value: 16.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Corridors 16.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
									Temp/ Grnd Refl	Sen/ Cool Tmp			Rm/ Heat Tmp	Ret/ Perm Len	Frc/ Loss Coef		

Room Description: 136-TECHNICAL SERVICES

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 357 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 80.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 80.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
									Temp/ Grnd Refl	Sen/ Cool Tmp			Rm/ Heat Tmp	Ret/ Perm Len	Frc/ Loss Coef		
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity								100	100	0	60.00

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 137-TECH SERVICES OFFICE

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 103 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 32.00 cfm</td> <td>32.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Office space	Office space	Vent Value: 32.00 cfm	32.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Office space	Office space																											
Vent Value: 32.00 cfm	32.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad	
									Temp/ Grnd Ref	Sen/ Cool Tmp			Rm/ Heat Tmp	Ret/ Perm Len	Frc/ Loss Coef			
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity								100	100		0	60.00

Room Description: 140-WORKROOM

Zone Description: VAV-07

System Description: VAV-07

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 165 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 22.00 cfm</td> <td>22.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Office space	Office space	Vent Value: 22.00 cfm	22.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Office space	Office space																											
Vent Value: 22.00 cfm	22.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad	
									Temp/ Grnd Ref	Sen/ Cool Tmp			Rm/ Heat Tmp	Ret/ Perm Len	Frc/ Loss Coef			
COPIERS (2X)	800.000 W		Misc - Low rise office			Electricity								100	100		0	60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 144-CONFERENCE ROOM

Zone Description: VAV-08

System Description: VAV-08

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 132 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:Room Room Type:Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 54.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 54.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
N	142 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
E	238 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																26 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 103-MAIL

Zone Description: VAV-09

System Description: VAV-09

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 130 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 2.9 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 14.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 14.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F					
S	112 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90									
A1				Window			90.1	Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00	
Misc Load 1	1.000 W/sq ft			Misc - Low rise office				Electricity					100	100	0 60.00
Floor - 1															8 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 147-LOANS SERV OPEN OFFICE

Zone Description: VAV-09

System Description: VAV-09

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 2,656 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 12 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 305.00 cfm</td> <td>305.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Office space	Office space	Vent Value: 305.00 cfm	305.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Office space	Office space																											
Vent Value: 305.00 cfm	305.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F	External Shading					
N	365 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	98	0.46	0.55	Overhang - None	None	0.00			
E1	50 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
E2	621 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	146	0.46	0.55	Overhang - None	None	0.00			
S	779 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	122	0.46	0.55	Overhang - None	None	0.00			
B1				Window			90.1 Window Zone 4-6	94	0.46	0.55	Overhang - None	None	0.00			
SPN-B1				Door			90.1-07 Min Swinging	44	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																122 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 149-CONFERENCE ROOM

Zone Description: VAV-10

System Description: VAV-10

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 121 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 2.9 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 57.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 57.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
E	214 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
S	144 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	62	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	16	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	35	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00
Floor - 1																24 0.73

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 219-CONFERENCE ROOM

Zone Description: VAV-11

System Description: VAV-11

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 84 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 20.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 20.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F	External Shading					
Roof - 1	84 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
W	149 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90					Overhang - None	None				
C1				Window			90.1 Window Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	18	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	33	0.00	0.70	Overhang - None	None	0.00			
N	142 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	18	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	33	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 220-CONFERENCE ROOM

Zone Description: VAV-12

System Description: VAV-12

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 69 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border: none;"> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> <tr> <td>Vent Type: Conference/ meeting</td> <td>Conference/ meeting</td> </tr> <tr> <td>Vent Value: 15.00 cfm</td> <td>15.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </table>	Cooling	Heating	Vent Type: Conference/ meeting	Conference/ meeting	Vent Value: 15.00 cfm	15.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Conference/ meeting	Conference/ meeting																											
Vent Value: 15.00 cfm	15.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading
Roof - 1	69 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
N	123 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	18	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	33	0.00	0.70	Overhang - None	None	0.00			
E	135 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
E1				Window			90.1 Window Zone 4-6	81	0.46	0.55	Overhang - None	None	0.00			
SPN-E1				Window			90.1 Window Zone 4-6	18	0.46	0.55	Overhang - None	None	0.00			
SPN				Window			90.1 Window Zone 4-6	35	0.46	0.55	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 201-LOBBY

Zone Description: VAV-13

System Description: VAV-13

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 1,200 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: Reception Area # of People: 5 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Reception areas Vent Value: 92.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Reception areas 92.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F						External Shading
Roof - 1	1,200 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
S	412 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1	Window	Zone 4-6	73	0.46	0.55	Overhang - None	None		0.00
K1				Window			90.1	Window	Zone 4-6	68	0.46	0.55	Overhang - None	None		0.00
SPN-K1				Window			90.1	Window	Zone 4-6	16	0.46	0.55	Overhang - None	None		0.00
SPN				Window			90.1	Window	Zone 4-6	32	0.46	0.55	Overhang - None	None		0.00
W	152 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90										
H1				Window			90.1	Window	Zone 4-6	85	0.46	0.55	Overhang - None	None		0.00
SPN-H1				Door			90.1-07	Min	Swinging	66	0.00	0.70	Overhang - None	None		0.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 221-CAP MNGMT OPEN OFFICE

Zone Description: VAV-14

System Description: VAV-14

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 3,214 ft ² Fir-Fir Height: 14.2 ft Plenum Height: 3.2 ft Height Above Fir: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 22 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 305.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 305.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef		
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² ·°F						External Shading	Internal Shading
Roof - 1	3,214 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70											
S1	334 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
B1				Window			90.1	Window Zone 4-6	83	0.46	0.55	Overhang - None	None	0.00			
SPN-B1				Door			90.1-07	Min Swinging	39	0.00	0.70	Overhang - None	None	0.00			
W	720 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window Zone 4-6	195	0.46	0.55	Overhang - None	None	0.00			
S2	28 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90											
N2	28 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90											
N1	549 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window Zone 4-6	98	0.46	0.55	Overhang - None	None	0.00			
F1				Window			90.1	Window Zone 4-6	72	0.46	0.55	Overhang - None	None	0.00			
SPN-F1				Door			90.1-07	Min Swinging	52	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office				Electricity							100	100	0 60.00
COPIER	400.000 W			Misc - Low rise office				Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 210-CONFERENCE ROOM

Zone Description: VAV-15

System Description: VAV-15

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 134 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 4 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 31.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 31.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
Roof - 1	134 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
S	227 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1	Window	Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00	
C1				Window			90.1	Window	Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00	
SPN-C1				Door			90.1-07	Min	Swinging	18	0.00	0.70	Overhang - None	None	0.00	
SPN				Door			90.1-07	Min	Swinging	33	0.00	0.70	Overhang - None	None	0.00	
W	142 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1	Window	Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00	
SPN-C1				Door			90.1-07	Min	Swinging	18	0.00	0.70	Overhang - None	None	0.00	
SPN				Door			90.1-07	Min	Swinging	33	0.00	0.70	Overhang - None	None	0.00	
Misc Load 1	0.500 W/sq ft			Misc - Low rise office					Electricity							100 100 0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 207-CONFERENCE ROOM

Zone Description: VAV-16

System Description: VAV-16

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 94 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 2 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 20.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 20.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	94 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
S	135 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1	Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00		
Misc Load 1	0.500 W/sq ft			Misc - Low rise office				Electricity						100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 223-CONFERENCE ROOM

Zone Description: VAV-17

System Description: VAV-17

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 478 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 15 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 76.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 76.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F					
Roof - 1	478 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70									
N	398 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90									
A1				Window			90.1	Window Zone 4-6	98	0.46	0.55	Overhang - None	None	0.00	
W	43 ft ²	270	0	90.1-07 Min Wall Nonres	0.0646	0.90									
Misc Load 1	0.500 W/sq ft			Misc - Low rise office				Electricity					100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 225-CAPITAL VENTURE OPEN OFFICE

Zone Description: VAV-18

System Description: VAV-18

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 400 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 64.00 cfm</td> <td>64.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Office space	Office space	Vent Value: 64.00 cfm	64.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Office space	Office space																											
Vent Value: 64.00 cfm	64.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F						External Shading
Roof - 1	400 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity						100	100	0	60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 232-CONFERENCE ROOM

Zone Description: VAV-19

System Description: VAV-19

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 132 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 35.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 35.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
Roof - 1	132 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70										
N	135 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90										
C1				Window			90.1 Window Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	18	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	33	0.00	0.70	Overhang - None	None	0.00			
E	227 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90										
A1				Window			90.1 Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
C1				Window			90.1 Window Zone 4-6	68	0.46	0.55	Overhang - None	None	0.00			
SPN-C1				Door			90.1-07 Min Swinging	18	0.00	0.70	Overhang - None	None	0.00			
SPN				Door			90.1-07 Min Swinging	33	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	0.500 W/sq ft			Misc - Low rise office			Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 237-LENDING OPEN OFFICE

Zone Description: VAV-20

System Description: VAV-20

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 3,066 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 16 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 330.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 330.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F	External Shading						Internal Shading
Roof - 1	3,066 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70											
N	345 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90					Overhang - None	None					
A1				Window			90.1	Window Zone 4-6	98	0.46	0.55	Overhang - None	None	0.00			
E2	47 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90											
E1	589 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window Zone 4-6	146	0.46	0.55	Overhang - None	None	0.00			
S	918 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window Zone 4-6	171	0.46	0.55	Overhang - None	None	0.00			
B1				Window			90.1	Window Zone 4-6	83	0.46	0.55	Overhang - None	None	0.00			
SPN-B1				Door			90.1-07	Min Swinging	39	0.00	0.70	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office				Electricity							100	100	0 60.00

ENTERED VALUES

ROOM BY ROOM

By THORNTON TOMASETTI, INC.

Room Description: 224-KITCHENETTE

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 332 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 3 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.2 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Break Rooms</td> <td>Break Rooms</td> </tr> <tr> <td>Vent Value: 73.00 cfm</td> <td>73.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Break Rooms	Break Rooms	Vent Value: 73.00 cfm	73.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Break Rooms	Break Rooms																											
Vent Value: 73.00 cfm	73.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
								Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							
Roof - 1	332 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70					Overhang - None	None					
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity							100	100	0	60.00

Room Description: 228-CORRIDOR

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 207 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6* AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.5 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Corridors</td> <td>Corridors</td> </tr> <tr> <td>Vent Value: 20.00 cfm</td> <td>20.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Corridors	Corridors	Vent Value: 20.00 cfm	20.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Corridors	Corridors																											
Vent Value: 20.00 cfm	20.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			External Shading	Internal Shading	Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
								Shade Coef	U Value Btu/h·ft ² ·°F	Area ft ²							
Roof - 1	207 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70					Overhang - None	None					

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 248-WORK AREA

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 186 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 5.7 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 2 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 27.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating Office space 27.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
							Temp/ Grnd Ref	Sen/ Cool Tm			Rm/ Heat Tm	Ret/ Perm Len	Frc/ Loss Coef		
COPIER	400.000 W		Misc - Low rise office			Electricity						100	100		0 60.00

Room Description: 249-MENS TOILET

Zone Description: VAV-21

System Description: VAV-21

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 165 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 5.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 0 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 0.9 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Rest Room Vent Value: 12.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%) Heating Rest Room 12.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft ² ·°F	Alpha	Type / Energy Type	Glass		External Shading	Internal Shading	Adj	Pct	Pct	Pct	Rad
							Temp/ Grnd Ref	Sen/ Cool Tm			Rm/ Heat Tm	Ret/ Perm Len	Frc/ Loss Coef		
Roof - 1	165 ft ²	0	90 90.1-07 Min Roof Nonres	0.0476	0.70										

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 240-CONFERENCE ROOM

Zone Description: VAV-22

System Description: VAV-22

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 115 ft ² Flr-Flr Height: 14.2 ft Plenum Height: 3.2 ft Height Above Flr: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: Room Room Type: Conditioned	People Type: Conference Room # of People: 3 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 52.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 52.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Glass					Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h·ft ² ·°F	External Shading						Internal Shading
Roof - 1	115 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70											
E	206 ft ²	90	0	90.1-07 Min Wall Nonres	0.0646	0.90											
A1				Window			90.1	Window	Zone 4-6	24	0.46	0.55	Overhang - None	None			0.00
C1				Window			90.1	Window	Zone 4-6	68	0.46	0.55	Overhang - None	None			0.00
SPN-C1				Window			90.1	Window	Zone 4-6	18	0.46	0.55	Overhang - None	None			0.00
SPN				Window			90.1	Window	Zone 4-6	33	0.46	0.55	Overhang - None	None			0.00
S	137 ft ²	180	0	90.1-07 Min Wall Nonres	0.0646	0.90											
C1				Window			90.1	Window	Zone 4-6	68	0.46	0.55	Overhang - None	None			0.00
SPN-C1				Door			90.1-07	Min	Swinging	18	0.00	0.70	Overhang - None	None			0.00
SPN				Door			90.1-07	Min	Swinging	33	0.00	0.70	Overhang - None	None			0.00
Misc Load 1	0.500 W/sq ft			Misc - Low rise office					Electricity								100 100 0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 226-CCVI OFFICE

Zone Description: VAV-23

System Description: VAV-23

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 116 ft ² Fir-Fir Height: 14.2 ft Plenum Height: 3.2 ft Height Above Fir: 15 ft Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² -°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: Room Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 22.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Office space 22.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h-ft ² -°F	Alpha	Glass				Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef		
							Type / Energy Type	Area ft ²	Shade Coef	U Value Btu/h-ft ² -°F						External Shading	Internal Shading
Roof - 1	116 ft ²	0	90	90.1-07 Min Roof Nonres	0.0476	0.70											
N	185 ft ²	0	0	90.1-07 Min Wall Nonres	0.0646	0.90											
B1				Window			90.1	Window Zone 4-6	28	0.46	0.55	Overhang - None	None	0.00			
SPN-B1				Door			90.1-07	Min Swinging	13	0.00	0.70	Overhang - None	None	0.00			
A1				Window			90.1	Window Zone 4-6	24	0.46	0.55	Overhang - None	None	0.00			
Misc Load 1	1.000 W/sq ft			Misc - Low rise office				Electricity							100	100	0 60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 122-CONFERENCE ROOM

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 100 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 5.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:None Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: Conference Room # of People: 1 People People Sensible: 245 Btu/h People Latent : 155 Btu/h People Schedule: People - Low Rise Office Workstation: 0.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.3 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Conference/ meeting Vent Value: 9.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Heating Conference/ meeting 9.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
									U Value Btu/h·ft ² ·°F	U Value Btu/h·ft ² ·°F								
Misc Load 1	0.500 W/sq ft		Misc - Low rise office			Electricity									100	100	0	60.00

Room Description: 123-OFFICE

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 205 ft ² Flr-Flr Height: 14.9 ft Plenum Height: 6.4 ft Height Above Flr: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location:Room Floor Multiplier: 1 Humidistat Location:Room Room Multiplier: 1 CO2 Sensor Location:None Room Type:Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	Cooling Vent Type: Office space Vent Value: 19.00 cfm Vent Schedule: Vent - Low rise office Infil Type: IRS STANDARD Infil Value: 0.04 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		Office space 19.00 cfm IRS STANDARD 0.04 cfm/sq ft of wall To be calculated To be calculated

Description	Area/ Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Area ft ²	Shade Coef	Glass		External Shading	Internal Shading	Adj Temp/ Grnd Ref	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef	
									U Value Btu/h·ft ² ·°F	U Value Btu/h·ft ² ·°F								
Misc Load 1	1.000 W/sq ft		Misc - Low rise office			Electricity									100	100	0	60.00

ENTERED VALUES
ROOM BY ROOM
 By THORNTON TOMASETTI, INC.

Room Description: 124-OFFICE

Zone Description: VAV-24

System Description: VAV-24

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION																										
Floor Area: 158 ft ² Fir-Fir Height: 14.9 ft Plenum Height: 6.4 ft Height Above Fir: Slab Cnstr Type: 6" AVE CONCRETE Room Mass: Time delay based on actual mass Ceiling R-Value: 1.786 hr-ft ² ·°F/Btu Is There Carpet?: YES Design Clg DB / Drift Point: 73.0 °F / 75.0 °F Design Htg DB / Drift Point: 70.0 °F / 68.0 °F Design Relative Humidity: 50 % Moisture Capacitance: None Clg Tstat: None Htg Tstat: None Thermostat Location: None Floor Multiplier: 1 Humidistat Location: Room Room Multiplier: 1 CO2 Sensor Location: None Room Type: Conditioned	People Type: General Office Space # of People: 1 People People Sensible: 250 Btu/h People Latent : 200 Btu/h People Schedule: People - Low Rise Office Workstation: 1.0 workstation/person LIGHTS Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Lights - Low rise office Lighting Amount: 1.1 W/sq ft Ballast Factor: 1.0	<table style="width: 100%; border: none;"> <thead> <tr> <th style="text-align: center;">Cooling</th> <th style="text-align: center;">Heating</th> </tr> </thead> <tbody> <tr> <td>Vent Type: Office space</td> <td>Office space</td> </tr> <tr> <td>Vent Value: 15.00 cfm</td> <td>15.00 cfm</td> </tr> <tr> <td>Vent Schedule: Vent - Low rise office</td> <td></td> </tr> <tr> <td>Infil Type: IRS STANDARD</td> <td>IRS STANDARD</td> </tr> <tr> <td>Infil Value: 0.04 cfm/sq ft of wall</td> <td>0.04 cfm/sq ft of wall</td> </tr> <tr> <td>Infil Schedule: Available (100%)</td> <td></td> </tr> <tr> <td>Vav Airflow:</td> <td></td> </tr> <tr> <td>Vav Sched: Available (100%)</td> <td></td> </tr> <tr> <td>Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Aux Supply: To be calculated</td> <td>To be calculated</td> </tr> <tr> <td>Room Exhaust:</td> <td></td> </tr> <tr> <td>Rm Exh Sched: Available (100%)</td> <td></td> </tr> </tbody> </table>	Cooling	Heating	Vent Type: Office space	Office space	Vent Value: 15.00 cfm	15.00 cfm	Vent Schedule: Vent - Low rise office		Infil Type: IRS STANDARD	IRS STANDARD	Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall	Infil Schedule: Available (100%)		Vav Airflow:		Vav Sched: Available (100%)		Supply: To be calculated	To be calculated	Aux Supply: To be calculated	To be calculated	Room Exhaust:		Rm Exh Sched: Available (100%)	
Cooling	Heating																											
Vent Type: Office space	Office space																											
Vent Value: 15.00 cfm	15.00 cfm																											
Vent Schedule: Vent - Low rise office																												
Infil Type: IRS STANDARD	IRS STANDARD																											
Infil Value: 0.04 cfm/sq ft of wall	0.04 cfm/sq ft of wall																											
Infil Schedule: Available (100%)																												
Vav Airflow:																												
Vav Sched: Available (100%)																												
Supply: To be calculated	To be calculated																											
Aux Supply: To be calculated	To be calculated																											
Room Exhaust:																												
Rm Exh Sched: Available (100%)																												

Description	Area/ Amount	Dir	Tilt	Const Type / Schedule	U Value Btu/h·ft ² ·°F	Alpha	Type / Energy Type	Glass			Adj Temp/ Grnd Refl	Pct Sen/ Cool Tmp	Pct Rm/ Heat Tmp	Pct Ret/ Perm Len	Rad Frc/ Loss Coef
								Shade Coef	U Value Btu/h·ft ² ·°F	External Shading					
Misc Load 1	1.000 W/sq ft			Misc - Low rise office			Electricity						100	100	0 60.00

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

RTU-1 - Variable Volume Reheat (30% Min Flow Default)

Design Air Conditions	Max	Min		
Cooling supply:			Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	110.0 °F	110.0 °F		

Economizer				
Type: Enthalpy	"On" Point:	Btu/lb	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Block	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: System	Return fan motor location: Omit	Optimum start schedule: Available (100%)		
Block cooling airflow: 10,575 cfm	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Block	CO2-based DCV: Single Setpoint		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: ASHRAE Std 62.1-2004-2010 w/ Vent Reset		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio: 28 %			
Reset per worst case room schedule: Available (100%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer: 100 %		
Max reset: 15.0	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: No	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
Supply air DB cooling low is 60.0 °F at outside air DB of 80.0 °F	Aux cooling coil losses to plenum: 0 %			
Supply air DB cooling high is 65.0 °F at outside air DB of 20.0 °F				
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Follow Outside Air Reset Schedule	Radiant Floor		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	268.0 Mbh	P14009-REHEAT COIL	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	100.0 % of Design minus Aux Capacity	Available (100%)	Misc loads 100%
Aux heating:	100 % of Design Capacity	Available (100%)	
Preheat:	100.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	AF Centrifugal var freq drv	2.8 in. wg	0.0 in. wg	0.00022 kW/Cfm-in wg	Available (100%)	92	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

RTU-2 - Variable Volume Reheat (30% Min Flow Default)

Design Air Conditions	Max	Min		
Cooling supply:			Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	110.0 °F	110.0 °F		

Economizer				
Type: Enthalpy	"On" Point:	Btu/lb	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Block	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: System	Return fan motor location: Omit	Optimum start schedule: Available (100%)		
Block cooling airflow: 10,290 cfm	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Block			
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: Single Setpoint		
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: ASHRAE Std 62.1-2004-2010 w/ Vent Reset		
	Std62 Max Vent (Z) Ratio: 45 %			
Reset per worst case room schedule: Available (100%)		Supply air path / duct location: Return Air		
Max reset: 15.0		Space convective gains to occupied layer: 100 %		
Use system default outside air reset: No		Underfloor plenum height: 0.0 ft		
Supply air DB cooling low is 60.0 °F at outside air DB of 80.0 °F		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Supply air DB cooling high is 65.0 °F at outside air DB of 20.0 °F		Upstream nominal leakage fraction: 0 %		
		Downstream constant leakage fraction: 0 %		
		Aux cooling coil losses to plenum: 0 %		
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Follow Outside Air Reset Schedule	Radiant Floor		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	268.0 Mbh	P14009-REHEAT COIL	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	100.0 % of Design minus Aux Capacity	Available (100%)	Misc loads 100%
Aux heating:	100 % of Design Capacity	Available (100%)	
Preheat:	100.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	AF Centrifugal var freq drv	2.8 in. wg	0.0 in. wg	0.00022 kW/Cfm-in wg	Available (100%)	92	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

HP-07 - Water Source Heat Pump

Design Air Conditions	Max	Min
Cooling supply: Leaving cooling coil: Heating supply:		
	Supply duct temperature diff: 0.0 °F Reheat Temperature diff: 0.0 °F	
	Design humidity ratio diff: Min room relative humidity:	

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Room Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Omit Supply fan configuration: Blow Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Off (0%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: 100 % Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr·ft²·°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan			
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils	Capacity	Schedule	Diversity
Main cooling:	23.8 Mbh	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	100.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	100.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	Hydronic in heat pump fan	0.5 in. wg	0.0 in. wg	0.25000 kW	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

SEMI-HEATED - Radiation (Heating Only)

Design Air Conditions

Max Min

Cooling supply: Leaving cooling coil: Heating supply:	Supply duct temperature diff: 0.0 °F Reheat Temperature diff: 0.0 °F	Design humidity ratio diff: Min room relative humidity:
---	---	--

Advanced Options

Cooling coil sizing method: No Coil Cooling coil location: Room Block cooling airflow: Ventilation deck location: Room Direct Supply duct location: Return Air Return air path: ROOMDK	Supply fan motor location: Omit Return fan motor location: Omit Supply fan configuration: Draw Thru Supply fan sizing: No Fan Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Off (0%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: 100 % Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr·ft²·°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %
	Control Method Control Type	
Auxiliary cooling coil Auxiliary heating coil Auxiliary fan	Activate After Primary System Activate After Primary System No Fan	None None

Coils

Capacity

Schedule

Diversity

Main cooling: 0.0 % of Design Capacity by adjusting airfl	Available (100%)	People 100%
Aux cooling:	Available (100%)	Lights 100%
Main heating: 100.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:	Available (100%)	
Preheat: 100.0% of Design Capacity	Available (100%)	
Reheat: 100.0 % of Design Capacity	Available (100%)	
Humidification: 100.0 % of Design Capacity	Available (100%)	

Fans

Type

Static Press.

90.1 SP Adj

Full Load Energy Rate

Schedule

Efficiency

Priority

Primary	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
Fan Cycling					Cycle with occupancy	

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

UNCONDITIONED SPACES - Radiation (Heating Only)

Design Air Conditions	Max	Min
Cooling supply: Leaving cooling coil: Heating supply:		
	Supply duct temperature diff: 0.0 °F Reheat Temperature diff: 0.0 °F	
	Design humidity ratio diff: Min room relative humidity:	

Advanced Options

Cooling coil sizing method: No Coil Cooling coil location: Room Block cooling airflow: Ventilation deck location: Room Direct Supply duct location: Return Air Return air path: DUCTED	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: No Fan Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Off (0%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: 100 % Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr·ft²·°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%; text-align: center;">Control Method</th> <th style="width: 30%; text-align: center;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td style="text-align: center;">Activate After Primary System</td> <td style="text-align: center;">None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td style="text-align: center;">Activate After Primary System</td> <td style="text-align: center;">None</td> </tr> <tr> <td>Auxiliary fan</td> <td style="text-align: center;">No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan			
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils	Capacity	Schedule	Diversity
Main cooling:	0.0 % of Design Capacity by adjusting airfl	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	100.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	100.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling					Cycle with occupancy	

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

BASEBOARD - System 10 - 2010 - Heating Only & Ventilation, Electric

Design Air Conditions

	Max	Min		
Cooling supply:			Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	105.0 °F	105.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: No Coil	Supply fan motor location: Supply	Night purge schedule: Off (0%)
Cooling coil location: Room	Return fan motor location: Return	Optimum start schedule: Available (100%)
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: No Fan	
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None
Return air path: ROOMDK	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs
	Std62 Max Vent (Z) Ratio:	
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air
Max reset:		Space convective gains to occupied layer:
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu
		Upstream nominal leakage fraction: 0 %
		Downstream constant leakage fraction: 0 %
		Aux cooling coil losses to plenum: 0 %
	Control Method	Control Type
Auxiliary cooling coil	Activate After Primary System	None
Auxiliary heating coil	Activate After Primary System	None
Auxiliary fan	No Fan	

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

Primary	None	0.0 in. wg	0.0 in. wg	0.00000 kW/Cfm-in wg	Available (100%)	90
Secondary	FC Centrifugal Const Vol	0.5 in. wg	NA	0.00032 kW/Cfm-in wg	Available (100%)	85
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
Fan Cycling					Cycle with occupancy	

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

HP-07 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	54.0 °F	54.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer			
Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling			
Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)	

Advanced Options			
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)	
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)	
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)	
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None	
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs	
	Std62 Max Vent (Z) Ratio:		
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air	
Max reset:		Space convective gains to occupied layer:	
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft	
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu	
		Upstream nominal leakage fraction: 0 %	
		Downstream constant leakage fraction: 0 %	
		Aux cooling coil losses to plenum: 0 %	
	Control Method	Control Type	
Auxiliary cooling coil	Activate After Primary System	None	
Auxiliary heating coil	Activate After Primary System	None	
Auxiliary fan	No Fan		

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-01 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak			
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None		
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs		
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air		
Max reset:		Space convective gains to occupied layer:		
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft		
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
		Upstream nominal leakage fraction: 0 %		
		Downstream constant leakage fraction: 0 %		
		Aux cooling coil losses to plenum: 0 %		
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-02 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-03 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-04 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs
	Std62 Max Vent (Z) Ratio:	
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air
Max reset:		Space convective gains to occupied layer:
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu
		Upstream nominal leakage fraction: 0 %
		Downstream constant leakage fraction: 0 %
		Aux cooling coil losses to plenum: 0 %
	Control Method	Control Type
Auxiliary cooling coil	Activate After Primary System	None
Auxiliary heating coil	Activate After Primary System	None
Auxiliary fan	No Fan	

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0 % of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
Fan Cycling					Cycle with occupancy	

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-05 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-06 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling: 115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:	Available (100%)	Lights 100%
Main heating: 125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:	Available (100%)	
Preheat: 125.0% of Design Capacity	Available (100%)	
Reheat: 100.0 % of Design Capacity	Available (100%)	
Humidification: 100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-07 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-08 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak			
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None		
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs		
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air		
Max reset:		Space convective gains to occupied layer:		
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft		
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
		Upstream nominal leakage fraction: 0 %		
		Downstream constant leakage fraction: 0 %		
		Aux cooling coil losses to plenum: 0 %		
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-09 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-10 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-11 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-12 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-13 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-14 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-15 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs								
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %								
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Control Method</th> <th style="width: 30%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> </tr> </tbody> </table>	Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	Auxiliary heating coil	Activate After Primary System	Auxiliary fan	No Fan	
Control Method	Control Type									
Auxiliary cooling coil	Activate After Primary System									
Auxiliary heating coil	Activate After Primary System									
Auxiliary fan	No Fan									

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-16 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-17 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-18 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-19 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer:		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-20 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	90.0 °F	90.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air			
Max reset:	Space convective gains to occupied layer:			
Use system default outside air reset: Yes	Underfloor plenum height: 0.0 ft			
	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu			
	Upstream nominal leakage fraction: 0 %			
	Downstream constant leakage fraction: 0 %			
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-21 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer			
Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling			
Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)	

Advanced Options			
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)	
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)	
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)	
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	CO2-based DCV: None	
Return air path: PLENUM	Apply Std62 People Avg: No	System ventilation flag: Sum Room OA Reqs	
	Std62 Max Vent (Z) Ratio:		
Reset per worst case room schedule: Off (0%)		Supply air path / duct location: Return Air	
Max reset:		Space convective gains to occupied layer:	
Use system default outside air reset: Yes		Underfloor plenum height: 0.0 ft	
		Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu	
		Upstream nominal leakage fraction: 0 %	
		Downstream constant leakage fraction: 0 %	
		Aux cooling coil losses to plenum: 0 %	
	Control Method	Control Type	
Auxiliary cooling coil	Activate After Primary System	None	
Auxiliary heating coil	Activate After Primary System	None	
Auxiliary fan	No Fan		

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-22 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan			
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling: 115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:	Available (100%)	Lights 100%
Main heating: 125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:	Available (100%)	
Preheat: 125.0% of Design Capacity	Available (100%)	
Reheat: 100.0 % of Design Capacity	Available (100%)	
Humidification: 100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-23 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: Peak	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Zone	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: Peak	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: PLENUM	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air			
Max reset:	Space convective gains to occupied layer:			
Use system default outside air reset: Yes	Underfloor plenum height: 0.0 ft			
	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu			
	Upstream nominal leakage fraction: 0 %			
	Downstream constant leakage fraction: 0 %			
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90	
Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

VAV-24 - System 4 - 2007/2010 - Packaged Rooftop Heat Pump

Design Air Conditions

	Max	Min		
Cooling supply:	53.0 °F	53.0 °F	Supply duct temperature diff: 0.0 °F	Design humidity ratio diff:
Leaving cooling coil:			Reheat Temperature diff: 0.0 °F	Min room relative humidity:
Heating supply:	90.0 °F	90.0 °F		

Economizer

Type: Dry Bulb	"On" Point: 70 °F	Max Percent OA: 100%	Schedule: Available (100%)
----------------	-------------------	----------------------	----------------------------

Evaporative Cooling

Type: None	Direct efficiency: 0% Available (100%)	Indirect efficiency: 0% Available (100%)
------------	--	--

Advanced Options

Cooling coil sizing method: Peak Cooling coil location: Zone Block cooling airflow: Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air Return air path: PLENUM	Supply fan motor location: Supply Return fan motor location: Return Supply fan configuration: Draw Thru Supply fan sizing: Peak Fan mechanical efficiency : 75% Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	Night purge schedule: Off (0%) Optimum start schedule: Available (100%) Optimum stop schedule: Off (0%) CO2-based DCV: None System ventilation flag: Sum Room OA Reqs												
Reset per worst case room schedule: Off (0%) Max reset: Use system default outside air reset: Yes		Supply air path / duct location: Return Air Space convective gains to occupied layer: Underfloor plenum height: 0.0 ft Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu Upstream nominal leakage fraction: 0 % Downstream constant leakage fraction: 0 % Aux cooling coil losses to plenum: 0 %												
	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 30%;">Control Method</th> <th style="width: 40%;">Control Type</th> </tr> </thead> <tbody> <tr> <td>Auxiliary cooling coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary heating coil</td> <td>Activate After Primary System</td> <td>None</td> </tr> <tr> <td>Auxiliary fan</td> <td>No Fan</td> <td></td> </tr> </tbody> </table>		Control Method	Control Type	Auxiliary cooling coil	Activate After Primary System	None	Auxiliary heating coil	Activate After Primary System	None	Auxiliary fan	No Fan		
	Control Method	Control Type												
Auxiliary cooling coil	Activate After Primary System	None												
Auxiliary heating coil	Activate After Primary System	None												
Auxiliary fan	No Fan													

Coils Capacity Schedule Diversity

Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans Type Static Press. 90.1 SP Adj Full Load Energy Rate Schedule Efficiency Priority

	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary	FC Centrifugal Const Vol	0.5 in. wg	0.0 in. wg	0.00032 kW/Cfm-in wg	Available (100%)	90
	Secondary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90
	Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85
	Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90
	Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85
	Fan Cycling				Cycle with occupancy		

SYSTEM ENTERED VALUES

By THORNTON TOMASETTI, INC.

UNCONDITIONED - System 10 - 2010 - Heating Only & Ventilation, Electric

Design Air Conditions	Max	Min		
Cooling supply:	55.0 °F	55.0 °F	Supply duct temperature diff:	0.0 °F
Leaving cooling coil:			Reheat Temperature diff:	0.0 °F
Heating supply:	105.0 °F	105.0 °F	Design humidity ratio diff:	
			Min room relative humidity:	

Economizer				
Type: Dry Bulb	"On" Point: 70	°F	Max Percent OA: 100%	Schedule: Available (100%)

Evaporative Cooling				
Type: None	Direct efficiency: 0%	Available (100%)	Indirect efficiency: 0%	Available (100%)

Advanced Options				
Cooling coil sizing method: No Coil	Supply fan motor location: Supply	Night purge schedule: Off (0%)		
Cooling coil location: Room	Return fan motor location: Return	Optimum start schedule: Available (100%)		
Block cooling airflow:	Supply fan configuration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck	Supply fan sizing: No Fan	CO2-based DCV: None		
Supply duct location: Return Air	Fan mechanical efficiency : 75%	System ventilation flag: Sum Room OA Reqs		
Return air path: ROOMDK	Apply Std62 People Avg: No			
	Std62 Max Vent (Z) Ratio:			
Reset per worst case room schedule: Off (0%)	Supply air path / duct location: Return Air	Space convective gains to occupied layer: 100 %		
Max reset:	Underfloor plenum height: 0.0 ft	Conductive resistance of raised floor: 0.8 hr-ft ² -°F/Btu		
Use system default outside air reset: Yes	Upstream nominal leakage fraction: 0 %	Downstream constant leakage fraction: 0 %		
	Aux cooling coil losses to plenum: 0 %			
	Control Method	Control Type		
Auxiliary cooling coil	Activate After Primary System	None		
Auxiliary heating coil	Activate After Primary System	None		
Auxiliary fan	No Fan			

Coils	Capacity	Schedule	Diversity
Main cooling:	115.0 % of Design Cooling Capacity	Available (100%)	People 100%
Aux cooling:		Available (100%)	Lights 100%
Main heating:	125.0 % of Design Capacity	Available (100%)	Misc loads 100%
Aux heating:		Available (100%)	
Preheat:	125.0% of Design Capacity	Available (100%)	
Reheat:	100.0 % of Design Capacity	Available (100%)	
Humidification:	100.0 % of Design Capacity	Available (100%)	

Fans	Type	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
Primary	None	0.0 in. wg	0.0 in. wg	0.00000 kW/Cfm-in wg	Available (100%)	90	
Secondary	FC Centrifugal Const Vol	0.0 in. wg	NA	0.00032 kW/Cfm-in wg	Available (100%)	85	
Return	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
System Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Room Exhaust	None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional ventilation	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
Auxiliary	None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
Fan Cycling					Cycle with occupancy		

BRUNSWICK (NAS), ME, USA

WMO#: 743920

Lat: **43.90N** Long: **69.93W** Elev: **75** StdP: **14.66** Time Zone: **-5 (NAE)** Period: **86-10** WBAN: **14611**

Annual Heating and Humidification Design Conditions

Coldest Month	Heating DB			Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB	
				99.6%			99%			0.4%		1%			
	99.6%	99%		DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
1	-2.2	2.1	-18.5	2.0	1.3	-13.4	2.7	5.8	26.6	32.2	24.3	26.3	5.1	0	

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	86.3	70.7	82.8	68.9	80.5	67.3	73.5	82.4	71.5	79.8	69.7	76.5	9.2	200

Dehumidification DP/MCDB and HR										Enthalpy/MCDB						Hours 8 to 4 & 55/69
0.4%			1%			2%			0.4%		1%		2%			
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
70.4	112.4	78.0	69.0	106.7	76.0	66.9	99.3	73.8	37.1	82.6	35.3	79.9	33.8	76.5	774	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Max WB	Extreme Annual DB						n-Year Return Period Values of Extreme DB							
1%	2.5%	5%		Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.2	19.5	17.4	84.7	-11.2	93.1	5.5	2.7	-15.1	95.0	-18.4	96.6	-21.4	98.1	-25.4	100.1		

Monthly Climatic Design Conditions

		Annual (d)	Jan (e)	Feb (f)	Mar (g)	Apr (h)	May (i)	Jun (j)	Jul (k)	Aug (l)	Sep (m)	Oct (n)	Nov (o)	Dec (p)			
(5) (6) (7) (8) (9) (10) (11) (12)	Temperatures, Degree-Days and Degree-Hours	Tavg	46.3	21.9	23.7	32.9	43.9	54.2	63.7	69.0	68.5	60.1	48.9	38.8	28.1		
		Sd		10.72	9.55	8.82	6.13	6.42	6.35	5.16	5.16	6.36	6.99	8.17	9.45		
		HDD50	3504	872	736	531	202	26	0	0	5	107	346	679			
		HDD65	7202	1337	1156	994	634	341	97	20	24	170	500	785	1144		
		CDD50	2144	0	0	2	18	157	412	589	575	307	73	11	0		
		CDD65	367	0	0	0	0	7	59	144	133	23	1	0	0		
		CDH74	2622	0	0	2	5	102	482	1009	877	140	5	0	0		
CDH80	676	0	0	1	0	26	122	278	224	25	0	0	0				
(13) (14) (15) (16)	Precipitation	PrecAvg	46.6	3.6	3.6	4.3	3.9	3.8	3.6	2.9	3.4	3.4	3.9	5.0	4.6		
		PrecMax	63.5	10.8	7.3	8.0	5.8	6.5	6.7	5.9	8.1	5.2	8.6	10.3	10.0		
		PrecMin	32.6	0.5	1.4	0.8	1.1	0.6	0.7	0.6	1.1	0.6	0.9	1.2	1.4		
		PrecSD	7.4	2.3	1.6	1.7	1.2	1.6	1.6	1.4	1.8	1.3	2.1	2.2	2.5		
(17) (18) (19) (20) (21) (22) (23) (24)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.8	48.3	61.3	70.6	83.8	88.3	90.9	90.2	83.1	73.6	63.5	53.9		
			MCWB	48.7	42.5	48.6	55.5	64.6	71.5	73.6	73.0	69.6	61.0	55.7	48.0		
		2%	DB	45.4	44.8	54.1	63.7	75.5	83.6	86.2	85.6	78.0	67.4	58.5	48.6		
			MCWB	41.5	40.4	45.1	49.9	61.5	67.2	70.7	71.6	65.3	57.6	53.5	44.8		
		5%	DB	40.7	41.3	48.6	59.0	70.5	79.5	82.5	82.0	73.8	63.6	54.9	45.3		
			MCWB	37.2	37.2	41.9	47.7	57.8	65.5	69.0	69.4	63.3	56.2	50.5	41.8		
		10%	DB	36.9	37.9	45.3	54.9	65.8	75.5	79.9	79.2	71.0	60.8	52.2	42.0		
			MCWB	33.9	34.0	39.5	45.4	54.5	63.4	67.7	66.8	62.3	54.4	48.2	37.8		
		(25) (26) (27) (28) (29) (30) (31) (32)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	45.3	51.7	58.7	67.6	74.3	77.0	75.7	71.2	64.2	58.5	51.1
					MCDB	50.2	46.4	56.7	67.8	77.6	84.2	86.3	85.3	78.8	68.6	61.9	53.0
				2%	WB	42.7	41.2	46.5	53.1	62.9	70.9	73.8	73.4	68.6	60.6	55.0	46.3
					MCDB	44.8	44.0	51.3	59.3	73.3	79.7	82.6	82.2	74.3	65.2	57.6	47.5
5%	WB			37.7	37.5	43.3	49.9	59.5	68.2	71.5	71.5	66.1	58.1	52.0	42.2		
	MCDB			40.2	40.1	48.1	56.3	68.0	75.9	79.9	79.4	71.3	62.3	54.4	45.1		
10%	WB			34.3	34.7	40.0	47.1	56.7	65.8	69.6	69.6	64.1	55.4	48.4	38.0		
	MCDB			36.7	37.9	44.4	53.0	63.6	72.7	76.4	75.9	68.1	59.0	51.2	41.3		
(33) (34) (35) (36) (37)	Mean Daily Temperature Range	5% DB	MDBR	17.5	18.4	17.2	18.3	19.1	18.7	18.4	18.8	18.7	18.4	16.1	16.5		
			MCDBR	18.5	18.6	22.1	25.9	27.1	24.4	23.0	22.3	22.1	21.8	18.4	19.3		
			MCWBR	16.8	15.2	15.3	15.2	14.7	12.7	11.3	11.4	12.6	14.8	14.8	16.8		
		5% WB	MCDWR	17.9	17.2	20.0	22.0	23.5	21.5	19.6	19.2	18.1	18.1	16.2	18.6		
			MCWBR	17.1	15.5	15.5	14.7	14.2	13.2	11.5	10.9	12.2	14.3	14.7	17.7		
(38) (39) (40) (41)	Clear Sky Solar Irradiance	taub	0.311	0.321	0.336	0.368	0.379	0.399	0.391	0.396	0.376	0.329	0.324	0.301			
		taud	2.536	2.469	2.448	2.336	2.296	2.238	2.300	2.313	2.385	2.563	2.601	2.641			
		Ebn,noon	261	277	287	284	283	276	277	272	269	272	255	257			
		Edh,noon	21	27	31	38	41	43	40	38	33	24	20	18			

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS						Btu/h·ft ² ·°F					Room Mass lb/ft ²	Room Capacitance Btu/lb·°F
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Summer Window	Winter Window	External Door	Wall	Ceiling		
Alternative 1													
128-A-BOARDROOM	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	89.2	19.7
VAV-01 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	89.2	19.7
128-B-BOARDROOM	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	78.7	17.3
VAV-02 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	78.7	17.3
112-126 - OPEN OFFICE	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	85.2	18.8
VAV-03 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	85.2	18.8
118-CONFERENCE ROOM	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	114.3	25.2
VAV-04 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	114.3	25.2
100-VESTIBULE	0.000	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	179.7	33.6
101-LOBBY	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.000	0.052	0.317	79.4	17.5
107-SITTING	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-05 - Zone	0.000	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	80.4	17.3
219-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	158.5	28.9
VAV-11 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	158.5	28.9
220-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	130.0	22.5
VAV-12 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	130.0	22.5
201-LOBBY	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	135.0	23.7
VAV-13 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	135.0	23.7
221-CAP MNGMT OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	143.0	25.4
VAV-14 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	143.0	25.4
210-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	166.7	30.7
VAV-15 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	166.7	30.7
207-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.000	0.052	0.317	185.6	34.9
VAV-16 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.000	0.052	0.317	185.6	34.9
122-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
123-OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
124-OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-24 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
RTU-1 - System	0.000	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	111.6	21.6
223-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.000	0.052	0.317	162.2	29.7
VAV-17 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.000	0.052	0.317	162.2	29.7

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS											Room Mass lb/ft ²	Room Capacitance Btu/lb·°F	
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Btu/h·ft ² ·°F		External Door	Wall	Ceiling			
							Summer Window	Winter Window						
225-CAPITAL VENTURE OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.000	0.317	125.5	21.6
VAV-18 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.000	0.317	125.5	21.6
232-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	164.5	30.2	30.2
VAV-19 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	164.5	30.2	30.2
237-LENDING OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	148.3	26.6	26.6
VAV-20 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	148.3	26.6	26.6
249-MENS TOILET	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6	21.6
250-WOMENS TOILET	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6	21.6
248-WORK AREA	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
224-KITCHENETTE	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6	21.6
228-CORRIDOR	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6	21.6
VAV-21 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	114.4	20.2	20.2
240-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	161.9	29.6	29.6
VAV-22 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	161.9	29.6	29.6
226-CCVI OFFICE	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	178.3	33.3	33.3
VAV-23 - Zone	0.000	0.000	0.000	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	178.3	33.3	33.3
130-STAFF LOUNGE	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.000	0.052	0.317	99.0	21.8	21.8
VAV-06 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.000	0.052	0.317	99.0	21.8	21.8
140-WORKROOM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
105-WOMENS TOILET	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
106-MENS TOILET	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
131-133-CORRIDOR	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
136-TECHNICAL SERVICES	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
137-TECH SERVICES OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
VAV-07 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8	13.8
144-CONFERENCE ROOM	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	112.7	24.9	24.9
VAV-08 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	112.7	24.9	24.9
147-LOANS SERV OPEN OFFICE	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	87.7	19.3	19.3
103-MAIL	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.000	0.052	0.317	96.9	21.4	21.4
VAV-09 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	88.1	19.4	19.4
149-CONFERENCE ROOM	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	107.8	23.8	23.8
VAV-10 - Zone	0.000	0.000	0.550	0.000	0.000	0.000	0.349	0.347	0.200	0.052	0.317	107.8	23.8	23.8

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS						Btu/h·ft ² ·°F					Room Mass lb/ft ²	Room Capacitance Btu/lb·°F
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Summer Window	Winter Window	External Door	Wall	Ceiling		
RTU-2 - System	0.000	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.317	114.7	22.2
138-SERVER	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
HP-07 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
HP-07 - System	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
001 - STAIR 2	0.096	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.000	505.6	100.6
BASEBOARD - Zone	0.096	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.000	505.6	100.6
SEMI-HEATED - System	0.096	0.000	0.550	0.000	0.000	0.023	0.349	0.347	0.200	0.052	0.000	505.6	100.6
108-TRASH/RECYCLE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
109-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
127-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
129-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
222-CLOSET (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6
247-JANITOR (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	125.5	21.6
002 - MECHANICAL ROOM (UNCOND)	0.096	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	165.8	34.5
UNCONDITIONED - Zone	0.096	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	145.5	30.1
UNCONDITIONED SPACES - System	0.096	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.317	145.5	30.1

Overall U-Factors		Overall Thermal Transfer Values	
Roof	0.023 Btu/h·ft ² ·°F	Roof (OTTVr)	0.35 Btu/hr·ft ²
Wall	0.165 Btu/h·ft ² ·°F	Wall (OTTVw)	26.79 Btu/hr·ft ²
Building	0.105 Btu/h·ft ² ·°F		

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS											Room Mass lb/ft ²	Room Capacitance Btu/lb·°F
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Btu/h·ft ² ·°F		External Door	Wall	Ceiling		
							Summer Window	Winter Window					
Alternative 2													
001 - STAIR 2	0.096	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.000	352.5	72.6
BASEBOARD - Zone	0.096	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.000	352.5	72.6
BASEBOARD - System	0.096	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.000	352.5	72.6
138-SERVER	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
HP-07 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
HP-07 - System	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
128-A-BOARDROOM	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	67.7	14.9
VAV-01 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	67.7	14.9
VAV-01 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	67.7	14.9
128-B-BOARDROOM	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	65.6	14.5
VAV-02 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	65.6	14.5
VAV-02 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	65.6	14.5
112-126 - OPEN OFFICE	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	66.9	14.8
VAV-03 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	66.9	14.8
VAV-03 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	66.9	14.8
118-CONFERENCE ROOM	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	72.5	16.1
VAV-04 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	72.5	16.1
VAV-04 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	72.5	16.1
100-VESTIBULE	0.000	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	74.0	16.4
101-LOBBY	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.000	0.065	0.317	65.8	14.5
107-SITTING	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-05 - Zone	0.000	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	65.2	14.4
VAV-05 - System	0.000	0.000	0.730	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	65.2	14.4
130-STAFF LOUNGE	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.000	0.065	0.317	69.5	15.4
VAV-06 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.000	0.065	0.317	69.5	15.4
VAV-06 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.000	0.065	0.317	69.5	15.4
131-133-CORRIDOR	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
136-TECHNICAL SERVICES	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
137-TECH SERVICES OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
106-MENS TOILET	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
105-WOMENS TOILET	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS							Btu/h·ft ² ·°F					Room Mass lb/ft ²	Room Capacitance Btu/lb·°F
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Summer Window	Winter Window	External Door	Wall	Ceiling			
140-WORKROOM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-07 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-07 - System	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
144-CONFERENCE ROOM	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	72.2	16.0
VAV-08 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	72.2	16.0
VAV-08 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	72.2	16.0
103-MAIL	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.000	0.065	0.317	0.317	69.1	15.3
147-LOANS SERV OPEN OFFICE	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	67.4	14.9
VAV-09 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	67.5	14.9
VAV-09 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	67.5	14.9
149-CONFERENCE ROOM	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	71.3	15.8
VAV-10 - Zone	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	71.3	15.8
VAV-10 - System	0.000	0.000	0.730	0.000	0.000	0.000	0.550	0.546	0.700	0.065	0.317	0.317	71.3	15.8
219-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	69.9	15.4
VAV-11 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	69.9	15.4
VAV-11 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	69.9	15.4
220-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	64.4	14.1
VAV-12 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	64.4	14.1
VAV-12 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	64.4	14.1
201-LOBBY	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	65.3	14.4
VAV-13 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	65.3	14.4
VAV-13 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	65.3	14.4
221-CAP MNGMT OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	66.9	14.7
VAV-14 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	66.9	14.7
VAV-14 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	66.9	14.7
210-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	71.5	15.8
VAV-15 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	71.5	15.8
VAV-15 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	0.317	71.5	15.8
207-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	0.317	75.1	16.6
VAV-16 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	0.317	75.1	16.6
VAV-16 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	0.317	75.1	16.6
223-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	0.317	70.6	15.6

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS											Room Mass lb/ft ²	Room Capacitance Btu/lb·°F
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Btu/h·ft ² ·°F		External Door	Wall	Ceiling		
							Summer Window	Winter Window					
VAV-17 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	70.6	15.6
VAV-17 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.000	0.065	0.317	70.6	15.6
225-CAPITAL VENTURE OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
VAV-18 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
VAV-18 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
232-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	71.0	15.7
VAV-19 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	71.0	15.7
VAV-19 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	71.0	15.7
237-LENDING OPEN OFFICE	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	67.9	15.0
VAV-20 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	67.9	15.0
VAV-20 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	67.9	15.0
224-KITCHENETTE	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
228-CORRIDOR	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
249-MENS TOILET	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
250-WOMENS TOILET	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
248-WORK AREA	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-21 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.3	13.9
VAV-21 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.3	13.9
240-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	70.5	15.6
VAV-22 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	70.5	15.6
VAV-22 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	70.5	15.6
226-CCVI OFFICE	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	73.7	16.3
VAV-23 - Zone	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	73.7	16.3
VAV-23 - System	0.000	0.000	0.000	0.000	0.000	0.048	0.550	0.546	0.700	0.065	0.317	73.7	16.3
124-OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
123-OFFICE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
122-CONFERENCE ROOM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-24 - Zone	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
VAV-24 - System	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
002 - MECHANICAL ROOM (UNCOND)	0.096	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	165.8	34.5
247-JANITOR (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0
222-CLOSET (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.317	63.5	14.0

BUILDING U-FACTORS

By THORNTON TOMASETTI, INC.

Description	ROOM U-FACTORS											Room Mass lb/ft ²	Room Capacitance Btu/lb·°F	
	Partition	Internal Door	Exposed Floor	Summer Skylight	Winter Skylight	Roof	Btu/h·ft ² ·°F		External Door	Wall	Ceiling			
							Summer Window	Winter Window						
127-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
129-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
109-STORAGE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
108-TRASH/RECYCLE (UNCOND)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	62.5	13.8
UNCONDITIONED - Zone	0.096	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.317	142.1	29.7
UNCONDITIONED - System	0.096	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.317	142.1	29.7

Overall U-Factors		Overall Thermal Transfer Values	
Roof	0.048 Btu/h·ft ² ·°F	Roof (OTTVr)	4.36 Btu/hr·ft ²
Wall	0.289 Btu/h·ft ² ·°F	Wall (OTTVw)	30.34 Btu/hr·ft ²
Building	0.186 Btu/h·ft ² ·°F		



Caution: Photovoltaic system performance predictions calculated by PVWatts® include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts® inputs. For example, PV modules with better performance are not differentiated within PVWatts® from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at <http://sam.nrel.gov>) that allow for more precise and complex modeling of PV systems.

Disclaimer: The PVWatts® Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Alliance for Sustainable Energy, LLC ("Alliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide

any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL/ALLIANCE, AND ITS AFFILIATES, OFFICERS, AGENTS, AND EMPLOYEES AGAINST ANY CLAIM OR DEMAND, INCLUDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLIANCE "AS IS" AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOE/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDIRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PERFORMANCE OF THE MODEL.

RESULTS

77,628 kWh per Year *

Month	Solar Radiation (kWh / m ² / day)	AC Energy (kWh)	Energy Value (\$)
January	2.22	3,703	257
February	3.26	4,911	341
March	4.06	6,682	464
April	5.05	7,824	543
May	5.67	8,925	619
June	5.82	8,703	604
July	5.90	9,017	626
August	5.63	8,606	597
September	4.79	7,229	502
October	3.30	5,249	364
November	2.25	3,519	244
December	1.99	3,260	226
Annual	4.16	77,628	\$ 5,387

User Comments

97% sun (204) LG 305 watt modules

Location and Station Identification

Requested Location	Brunswick, ME
Weather Data Source	SolarAnywhere® from Clean Power (43.95, -69.95) 2.6 mi
Latitude	43.95° N
Longitude	69.95° W

PV System Specifications (Residential)

DC System Size	62.22 kW
Module Type	Premium
Array Type	Fixed (open rack)
Array Tilt	11.8°
Array Azimuth	153.5°
System Losses	14.08%
Inverter Efficiency	97.5%
DC to AC Size Ratio	1.13

Initial Economic Comparison

Average Cost of Electricity Purchased from Utility	0.07 \$/kWh
Initial Cost	3.30 \$/Wdc

Cost of Electricity Generated by System	0.22 \$/kWh
--	--------------------

These values can be compared to get an idea of the cost-effectiveness of this system. However, system costs, system financing options (including 3rd party ownership) and complex utility rates can significantly change the relative value of the PV system.

SYSTEM SUMMARY
DESIGN AIRFLOW QUANTITIES
 By THORNTON TOMASETTI, INC.

System Description	System Type	MAIN SYSTEM					Auxiliary System	Room
		Outside Airflow cfm	Cooling Airflow cfm	Heating Airflow cfm	Return Airflow cfm	Exhaust Airflow cfm	Supply Airflow cfm	Exhaust Airflow cfm
Alternative 1								
RTU-1	Variable Volume Reheat (30% Min Flow Default)	1,280	10,575	7,524	10,870	10,575	0	0
RTU-2	Variable Volume Reheat (30% Min Flow Default)	1,380	10,290	6,099	10,532	10,290	0	0
HP-07	Water Source Heat Pump	0	760	760	760	0	0	0
SEMI-HEATED UNCONDITIONED SPACES	Radiation (Heating Only)	0	0	0	0	137	0	0
	Radiation (Heating Only)	0	0	0	0	0	0	0
Totals		2,660	21,625	14,383	22,162	21,002	0	0
Alternative 2								
BASEBOARD	System 10 - 2010 - Heating Only & Ventilation, Electric	0	0	421	0	421	0	0
HP-07	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	0	406	406	406	406	0	0
VAV-01	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	204	1,017	1,017	1,045	1,017	0	0
VAV-02	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	204	948	948	969	948	0	0
VAV-03	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	184	1,185	1,185	1,225	1,185	0	0
VAV-04	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	31	610	610	625	610	0	0
VAV-05	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	130	1,522	1,522	1,587	1,522	0	0
VAV-06	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	54	468	468	486	468	0	0
VAV-07	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	174	375	375	375	375	0	0
VAV-08	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	54	604	604	618	604	0	0
VAV-09	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	319	2,186	2,186	2,259	2,186	0	0
VAV-10	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	57	594	594	607	594	0	0
VAV-11	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	20	493	493	504	493	0	0
VAV-12	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	15	544	544	554	544	0	0
VAV-13	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	92	1,139	1,139	1,161	1,139	0	0
VAV-14	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	305	2,163	2,163	2,226	2,163	0	0
VAV-15	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	31	552	552	566	552	0	0
VAV-16	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	20	162	162	167	162	0	0
VAV-17	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	76	568	568	585	568	0	0
VAV-18	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	64	162	162	162	162	0	0
VAV-19	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	35	550	550	564	550	0	0
VAV-20	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	330	2,449	2,449	2,521	2,449	0	0
VAV-21	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	144	333	333	333	333	0	0
VAV-22	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	52	623	623	636	623	0	0
VAV-23	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	22	211	211	218	211	0	0
VAV-24	System 4 - 2007/2010 - Packaged Rooftop Heat Pump	43	157	157	157	157	0	0
UNCONDITIONED	System 10 - 2010 - Heating Only & Ventilation, Electric	0	0	0	0	0	0	0
Totals		2,660	20,020	20,441	20,556	20,441	0	0

Note: Airflows on this report are not additive because they are each taken at the time of their respective peaks. To view the balanced system design airflows, see the appropriate Checksums report (Airflows section).

ECONOMIC PARAMETERS

By THORNTON TOMASETTI, INC.

Project Name:
Location:
Building Owner:
Program User:
Company:
Comments: WING_TEMPLATE_PROCESSING

Study Life:	20 Yrs	Income Tax Rate:	0.000 %
Mortgage Life:	20 Yrs	Cost of Capital:	10.000 %
Depreciation Life:	20 Yrs	Property tax rate:	0.000 %
Mortgage Interest Rate:	10.000 %	Insurance Expense rate:	0.000 %
Percent Financed:	0.0 %		
Depreciation Method:	None	<u>Annual Inflation Rate Of</u>	
Declining Balance Taxes:	100.0 %	Maintenance Expense	0.000 %
		Replacement Expense	0.000 %
		Property Taxes	0.000 %
		Insurance Expense	0.000 %

Alt #	First Cost (\$/ton)	First Cost (\$/ft ²)	Additional First Cost	Total First Cost	Maintenance Cost (\$/ton)	Maintenance Cost (\$/ft ²)	Total Maint. Cost	Total Alt. Cost
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Library Members

Exposed Floor - Construction Types

0001 - Default Floor 0

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	A0	Outside Surface Resist.					0.33 ft ² ·hr·°F/Btu
2	C4	12 in. LW Concrete	12.00 in.	0.10 Btu/hr-ft·°F	40.00 lb/cu ft	0.20 Btu/lb·°F	
3	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
Lamda = 0.28		Weight = 40.00 lb/ft ²	U-Value = 0.091 Btu/hr-ft ² ·°F		Alpha = 0.90		
Delta = 10 hours		Heat Capacity = 8.00 Btu/ft ² ·lb·°F	C-Coefficient = 0.0000 Btu/hr-ft ² ·°F				

Floor - Construction Types

6" AVE CONCRETE 0

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
2	M302	6 IN. NORMAL AGG CONCRET	6.00 in.	0.81 Btu/hr-ft·°F	125.00 lb/cu ft	0.22 Btu/lb·°F	
3	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
Lamda = 0.56		Weight = 62.50 lb/ft ²	U-Value = 0.503 Btu/hr-ft ² ·°F		Alpha = 0.90		
Delta = 5 hours		Heat Capacity = 13.75 Btu/ft ² ·lb·°F	C-Coefficient = 0.0700 Btu/hr-ft ² ·°F				

Partitions - Construction Types

8" HW Conc, 2" EPS 8" poured heavyweight concrete

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
2	M317	2 in. Insulation - EPS	2.00 in.	0.02 Btu/hr-ft·°F	2.50 lb/cu ft	0.29 Btu/lb·°F	
3	C8	8 in. HW Concrete	8.00 in.	1.00 Btu/hr-ft·°F	140.00 lb/cu ft	0.20 Btu/lb·°F	
4	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
Lamda = 0.23		Weight = 93.75 lb/ft ²	U-Value = 0.096 Btu/hr-ft ² ·°F		Alpha = 0.90		
Delta = 7 hours		Heat Capacity = 18.79 Btu/ft ² ·lb·°F	C-Coefficient = 0.0000 Btu/hr-ft ² ·°F				

Library Members

Roof - Construction Types

P14009-ROOF B

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	A0	Outside Surface Resist.					0.33 ft ² ·hr·°F/Btu
2	M293	EPDM	0.13 in.	0.10 Btu/hr·ft·°F	70.00 lb/cu ft	0.30 Btu/lb·°F	
3	M399	7" Poli Iso	7.00 in.	0.01 Btu/hr·ft·°F	2.00 lb/cu ft	0.22 Btu/lb·°F	
4	M162	Metal Deck	1.50 in.	26.20 Btu/hr·ft·°F	489.00 lb/cu ft	0.12 Btu/lb·°F	
5	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
Lamda = 0.57		Weight = 63.02 lb/ft ²	U-Value = 0.023 Btu/hr·ft ² ·°F		Alpha = 0.55		
Delta = 5 hours		Heat Capacity = 7.81 Btu/ft ² ·lb·°F	C-Coefficient = 0.0000 Btu/hr·ft ² ·°F				

90.1-07 Min Roof Nonres Zor 90.1-07 App A roof with insul above deck, Table A2.2

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	M132	90.1-07 Min ext air film					0.17 ft ² ·hr·°F/Btu
2	M142	90.1-07 Min roof insul R-20 ci	6.00 in.	0.02 Btu/hr·ft·°F	2.00 lb/cu ft	0.20 Btu/lb·°F	
3	M135	90.1-07 Min Roof metal deck	0.00 in.	0.00 Btu/hr·ft·°F	0.00 lb/cu ft	0.00 Btu/lb·°F	
4	M130	90.1-07 Min Roof int air film					0.61 ft ² ·hr·°F/Btu
Lamda = 0.98		Weight = 1.00 lb/ft ²	U-Value = 0.048 Btu/hr·ft ² ·°F		Alpha = 0.70		
Delta = 1 hours		Heat Capacity = 0.20 Btu/ft ² ·lb·°F	C-Coefficient = 0.0400 Btu/hr·ft ² ·°F				

Library Members

Wall - Construction Types

P14009-WALL

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	A0	Outside Surface Resist.					0.33 ft ² ·hr·°F/Btu
2	A2	4 in. Face Brick	4.00 in.	0.75 Btu/hr-ft·°F	130.00 lb/cu ft	0.22 Btu/lb·°F	
3	B0	Air Space Resistance					0.91 ft ² ·hr·°F/Btu
4	M317	2 in. Insulation - EPS	2.00 in.	0.02 Btu/hr-ft·°F	2.50 lb/cu ft	0.29 Btu/lb·°F	
5	M277	5/8 in. Gypsum Board	0.63 in.	0.09 Btu/hr-ft·°F	50.00 lb/cu ft	0.26 Btu/lb·°F	
6	M335	R-21 6" METAL STUD 16"OC	152.39 mm	0.12 W/m·°C	69.52 kb/cu m	0.63 kJ/kg·°C	
7	M277	5/8 in. Gypsum Board	0.63 in.	0.09 Btu/hr-ft·°F	50.00 lb/cu ft	0.26 Btu/lb·°F	
8	E0	Inside Surface Resist.					0.69 ft ² ·hr·°F/Btu
Lamda = 0.43		Weight = 51.13 lb/ft ²	U-Value = 0.052 Btu/hr-ft ² ·°F		Alpha = 0.90		
Delta = 8 hours		Heat Capacity = 11.33 Btu/ft ² ·lb·°F	C-Coefficient = 0.0000 Btu/hr-ft ² ·°F				

90.1-07 Min Wall Nonres Zone 4 90.1-07 App A steel-framed wall, standard framing 3.5" depth

Layer	Code	Description	Thickness	Conductivity	Density	Specific Heat	Resistance
1	M132	90.1-07 Min ext air film					0.17 ft ² ·hr·°F/Btu
2	M134	90.1-07 Min stucco	0.38 in.	0.40 Btu/hr-ft·°F	116.00 lb/cu ft	0.20 Btu/lb·°F	
3	M60	5/8 in. Gypsum Board-horiz	0.63 in.	0.09 Btu/hr-ft·°F	50.00 lb/cu ft	0.26 Btu/lb·°F	
4	M136	90.1-07 Min insulation R-13	3.50 in.	0.05 Btu/hr-ft·°F	2.00 lb/cu ft	0.20 Btu/lb·°F	
5	M137	90.1-07 Min insulation R-7.5 ci	2.25 in.	0.02 Btu/hr-ft·°F	2.00 lb/cu ft	0.20 Btu/lb·°F	
6	M60	5/8 in. Gypsum Board-horiz	0.63 in.	0.09 Btu/hr-ft·°F	50.00 lb/cu ft	0.26 Btu/lb·°F	
7	M131	90.1-07 Min int air film					0.68 ft ² ·hr·°F/Btu
Lamda = 0.97		Weight = 9.88 lb/ft ²	U-Value = 0.065 Btu/hr-ft ² ·°F		Alpha = 0.90		
Delta = 2 hours		Heat Capacity = 2.29 Btu/ft ² ·lb·°F	C-Coefficient = 0.0500 Btu/hr-ft ² ·°F				

Library Members

Glass types

90.1 Window Zone 4-6 Metal All Other

Properties based on Std DS Glass

Number of Panes	2	Visible Transmissivity	0.90	Inside Solar Reflectivity	0.15	
Shading Coeff	0.46	Inside Visible Reflectivity	0.15	Outside Long Wave Emissivity	0.90	
Glass U-Value	0.55	Btu/hr-ft ² -°F	Solar Transmissivity	0.90	Inside Long Wave Emissivity	0.90

Double Clear 1/4"

Properties based on Std DS Glass

Number of Panes	2	Visible Transmissivity	0.68	Inside Solar Reflectivity	0.18	
Shading Coeff	0.82	Inside Visible Reflectivity	0.23	Outside Long Wave Emissivity	0.84	
Glass U-Value	0.60	Btu/hr-ft ² -°F	Solar Transmissivity	0.50	Inside Long Wave Emissivity	0.84

Standard Door

Properties based on Std DS Glass

Number of Panes	1	Visible Transmissivity	0.00	Inside Solar Reflectivity	0.35	
Shading Coeff	0.00	Inside Visible Reflectivity	0.50	Outside Long Wave Emissivity	0.90	
Glass U-Value	0.20	Btu/hr-ft ² -°F	Solar Transmissivity	0.00	Inside Long Wave Emissivity	0.90

P14009-WINDOW

Properties based on Std DS Glass

Number of Panes	2	Visible Transmissivity	0.57	Inside Solar Reflectivity	0.24	
Shading Coeff	0.43	Inside Visible Reflectivity	0.20	Outside Long Wave Emissivity	0.84	
Glass U-Value	0.35	Btu/hr-ft ² -°F	Solar Transmissivity	0.24	Inside Long Wave Emissivity	0.84

90.1 Skylight Zone 4-6 Curb Glass 0-2%

Properties based on Std DS Glass

Number of Panes	2	Visible Transmissivity	0.90	Inside Solar Reflectivity	0.15	
Shading Coeff	0.56	Inside Visible Reflectivity	0.15	Outside Long Wave Emissivity	0.90	
Glass U-Value	1.17	Btu/hr-ft ² -°F	Solar Transmissivity	0.90	Inside Long Wave Emissivity	0.90

90.1-07 Min Swinging Nonres Zone 1-6

Properties based on Std DS Glass

Number of Panes	1	Visible Transmissivity	0.00	Inside Solar Reflectivity	0.35	
Shading Coeff	0.00	Inside Visible Reflectivity	0.50	Outside Long Wave Emissivity	0.90	
Glass U-Value	0.70	Btu/hr-ft ² -°F	Solar Transmissivity	0.00	Inside Long Wave Emissivity	0.90

Library Members

Infiltration

Neutral, Poor Const.

Cooling Design
1.00 air changes/hr

Heating Design
1.00 air changes/hr

Neutral, Loose Const.

Cooling Design
2.50 air changes/hr

Heating Design
2.50 air changes/hr

IRS STANDARD

Cooling Design
0.04 cfm/ft² of wall

Heating Design
0.04 cfm/ft² of wall

Lights

Recessed fluorescent, not vented, 80% load to space

Fixture Type RECFL-NV
Percent Lights to RA 20 %
Ballast Factor 1.00

Longwave Radiant Fraction 50 %
Shortwave Radiant Fraction 0 %

Misc. loads

Computer

Energy Consumption 150.00 W

Percent Sensible 100 %
Percent To Room 100 %
Percent To RA 0 %

Radiant Fraction 60 %
The energy meter is Electricity
The miscellaneous air path is Same Path As RA

Std Office Equipment

Energy Consumption 0.50 W/ft²

Percent Sensible 100 %
Percent To Room 100 %
Percent To RA 0 %

Radiant Fraction 60 %
The energy meter is Electricity

People

Member Name

Reception Area

People Density
16.70 ft²/person

Sensible Load
245.00 Btuh

Latent Load
155.00 Btuh

Longwave Radiant Fraction
70 %

Member Name

Conference Room

People Density
20.00 ft²/person

Sensible Load
245.00 Btuh

Latent Load
155.00 Btuh

Longwave Radiant Fraction
70 %

Member Name

General Office Space

People Density
143.00 ft²/person

Sensible Load
250.00 Btuh

Latent Load
200.00 Btuh

Longwave Radiant Fraction
70 %

Library Members

Ventilation

Member Name	People-based Rate (Rp)	Area-based Rate (Ra)
Office space	5.0 cfm/person	0.1 cfm/ft ²
Member Name	People-based Rate (Rp)	Area-based Rate (Ra)
Reception areas	5.0 cfm/person	0.1 cfm/ft ²
Member Name	Cooling Design	Heating Design
Rest Room	50.0 cfm/person	50.0 cfm/person
Member Name	People-based Rate (Rp)	Area-based Rate (Ra)
Conference/ meeting	5.0 cfm/person	0.1 cfm/ft ²
Member Name	People-based Rate (Rp)	Area-based Rate (Ra)
Break Rooms	5.0 cfm/person	0.1 cfm/ft ²
Member Name	People-based Rate (Rp)	Area-based Rate (Ra)
Corridors	0.0 cfm/person	0.1 cfm/ft ²

Library Members

Schedules

P14009-REHEAT COIL

Simulation type: Reduced year

January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	
Heating Design					
		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	
<u>Reset / Lockout</u>					
0	Outdr DB	>	70.00	F	

Parking lot lights

Simulation type: Reduced year

January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	100.0	
		7 a.m.	6 p.m.	0.0	
		6 p.m.	Midnight	100.0	
Heating Design					
		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	100.0	
		7 a.m.	6 p.m.	0.0	
		6 p.m.	Midnight	100.0	

Library Members

Schedules

P14009- Elevator

Simulation type: Reduced year

Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	
January - December Weekday		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	0.0	
		7 a.m.	8 a.m.	16.0	
		8 a.m.	9 a.m.	14.0	
		9 a.m.	10 a.m.	21.0	
		10 a.m.	11 a.m.	18.0	
		11 a.m.	noon	25.0	
		noon	1 p.m.	21.0	
		1 p.m.	2 p.m.	13.0	
		2 p.m.	3 p.m.	8.0	
		3 p.m.	4 p.m.	4.0	
		4 p.m.	5 p.m.	5.0	
		5 p.m.	8 p.m.	6.0	
		8 p.m.	Midnight	0.0	
January - December Cooling design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	
January - December Saturday to Sunday		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	0.0	
		7 a.m.	8 a.m.	35.0	
		8 a.m.	9 a.m.	69.0	
		9 a.m.	10 a.m.	43.0	
		10 a.m.	11 a.m.	37.0	
		11 a.m.	noon	43.0	
		noon	1 p.m.	58.0	
		1 p.m.	2 p.m.	48.0	

Library Members

Schedules

2 p.m.	4 p.m.	37.0
4 p.m.	5 p.m.	46.0
5 p.m.	6 p.m.	62.0
6 p.m.	7 p.m.	20.0
7 p.m.	8 p.m.	12.0
8 p.m.	10 p.m.	4.0
10 p.m.	Midnight	0.0

Library Members

Schedules

P14009-GRND TEMP PROFILE

Simulation type: Reduced year

January - January	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
February - February	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
March - March	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
April - April	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
May - May	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
June - June	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
July - July	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
August - August	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
September - September	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
October - October	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
November - November	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight
December - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>
		Midnight	Midnight

Library Members

Schedules

Lights - Low rise office

Simulation type: Reduced year

January - December	Cooling design to Weekday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	5.0	
		7 a.m.	8 a.m.	80.0	
		8 a.m.	10 a.m.	90.0	
		10 a.m.	noon	95.0	
		noon	2 p.m.	80.0	
		2 p.m.	4 p.m.	90.0	
		4 p.m.	5 p.m.	95.0	
		5 p.m.	6 p.m.	80.0	
		6 p.m.	7 p.m.	70.0	
		7 p.m.	8 p.m.	60.0	
		8 p.m.	9 p.m.	40.0	
		9 p.m.	10 p.m.	30.0	
		10 p.m.	Midnight	20.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	
January - December	Saturday to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	5.0	

Heatpump

Simulation type: Reduced year

January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Mode</u>	Thermal storage
		Midnight	Midnight	Satisfy load	

Library Members

Schedules

Hot water - Low rise office

Simulation type: Reduced year

January - December	Cooling design to Weekday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	8 a.m.	0.0	
		8 a.m.	10 a.m.	55.0	
		10 a.m.	11 a.m.	50.0	
		11 a.m.	noon	55.0	
		noon	1 p.m.	90.0	
		1 p.m.	2 p.m.	60.0	
		2 p.m.	3 p.m.	80.0	
		3 p.m.	4 p.m.	70.0	
		4 p.m.	5 p.m.	75.0	
		5 p.m.	7 p.m.	30.0	
		7 p.m.	8 p.m.	50.0	
		8 p.m.	9 p.m.	5.0	
		9 p.m.	Midnight	0.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	
January - December	Saturday to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	

Library Members

Schedules

Misc - Low rise office

Simulation type: Reduced year

January - December	Cooling design to Weekday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	5.0	
		7 a.m.	8 a.m.	80.0	
		8 a.m.	10 a.m.	90.0	
		10 a.m.	noon	95.0	
		noon	2 p.m.	80.0	
		2 p.m.	4 p.m.	90.0	
		4 p.m.	5 p.m.	95.0	
		5 p.m.	6 p.m.	80.0	
		6 p.m.	7 p.m.	70.0	
		7 p.m.	8 p.m.	60.0	
		8 p.m.	9 p.m.	40.0	
		9 p.m.	10 p.m.	30.0	
		10 p.m.	Midnight	20.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	
January - December	Saturday to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	5.0	

Library Members

Schedules

Vent - Low rise office

Simulation type: Reduced year

January - December	Cooling design to Weekday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	0.0	
		7 a.m.	Midnight	100.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	
January - December	Saturday to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	

People - Low Rise Office

Simulation type: Reduced year

January - December	Cooling design to Weekday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	7 a.m.	0.0	
		7 a.m.	8 a.m.	30.0	
		8 a.m.	11 a.m.	100.0	
		11 a.m.	noon	80.0	
		noon	1 p.m.	40.0	
		1 p.m.	2 p.m.	80.0	
		2 p.m.	5 p.m.	100.0	
		5 p.m.	6 p.m.	30.0	
		6 p.m.	9 p.m.	10.0	
		9 p.m.	Midnight	5.0	
January - December	Saturday to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	0.0	

Library Members

Schedules

On 100%

Simulation type: Reduced year

		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
Heating Design		Midnight	Midnight	0.0	
January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	6 a.m.	100.0	
		6 a.m.	10 p.m.	100.0	
		10 p.m.	Midnight	100.0	

Available (100%)

Simulation type: Reduced year

January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	
Heating Design		<u>Start time</u>	<u>End time</u>	<u>Percentage</u>	Utilization
		Midnight	Midnight	100.0	

Off (0%)

Simulation type: Reduced year

January - December	Cooling design to Sunday	<u>Start time</u>	<u>End time</u>	<u>Status</u>	Equipment operation
		Midnight	Midnight	Off	

Library Members

Utility Rates

P14009 - EIA MAINE COMM SEPT-2014

Electric consumption	Min Charge	0	Start period:	January	<u>Rate</u>	<u>Cutoff</u>
On peak	Min demand	0	End period:	December	\$/kW	0.127
	Fuel adjustment	0				
	kWh/kW flag	No				
	Customer charge	0				

Library Members

Base Utilities

Exhaust Fan

Comments	
Schedule	MP Time Clock Ventilation
Energy Type	Electricity
Hourly demand	1.00 kW
Entering	°F
Leaving	°F

Parking lot lights

Comments	
Schedule	Parking lot lights
Energy Type	Electricity
Hourly demand	0.10 kW
Entering	°F
Leaving	°F

DHW CIRC PUMP

Comments	
Schedule	On 100%
Energy Type	Electricity
Hourly demand	1.00 kW
Entering	°F
Leaving	°F

P14009-DHW

Comments	55EWT, 135LWT
Schedule	Hot water - Low rise office
Energy Type	Electricity
Hourly demand	1.00 gpm
Entering	55.00 °F
Leaving	135.00 °F

Elevator

Comments	
Schedule	MP Medical Office
Energy Type	Electricity
Hourly demand	18.65 kW
Entering	°F
Leaving	°F

Library Members

Cooling Equipment

TRACE® 700 Cooling Equipment Library

90.1-07 Min ACHP Elec SS/SP 65-135 MBh

Air-cooled unitary - Air to air heat pump

Comments: Air Cooled, Electrically Operated HP,CV, Elec Heating SS/SP

Operating Mode		Capacity		Energy Rate	Pumps		Type	Full Load Consumption	Pump Head
Cooling		tons		11.000 Packaged EER	Chilled water	None		0.000000kW	
Heat Recovery		Mbh/ton	14.40	3.300 Packaged COP	Condenser water	None		0.000000kW	
Tank Charging					Ht Rec or aux cond.	None		kW	
Tank Chrg. & Heat Rec.					Free cooling pump	None			
Unloading Curves		Primary		Secondary	Reset		Based On	Reset Curve	Max Reset TD
Power consumed	90.1 min Air to Air HP	90_1 AAHP Power Consumed C			Chilled water	None			
Ambient modification	90.1 Min Air-Air HP	90_1 AAHP Ambient Relief Curv			Condenser water	None			
Capacity		90.1 HP Htg Cap Curve			Chilled water temp Design leaving		44.00°F	Miscellaneous accessories Cntl panel & interlocks - 0.1 KW	
Load Shed Economizer	No				Chilled water temp Difference		12.00°F		
Evap Precooling	No				Condenser temp design temp entering		95.00°F		
Fuel Source	Heating plant				Condenser temp min. operating		17.00°F		
Fuel type	Electric				Condenser temp Difference		0.00°F		
Free cooling type	None				Reject Cond heat to ref		Heat rejection equipment		
Fluid cooler type	None				Reject Cond heat at water temp				
Thermal Storage	None								
Tower/condenser	90.1 Min Air Cooled Condenser								
Package energy breakout	Primary fan	Secondary fan	Exhaust fan	Optional ventilation fan	Condenser fan				
Included in full load energy rate	Yes	No	No	No	Yes				

Apply same fans for heat recovery energy breakout: Yes

Library Members

Cooling Equipment

TRACE® 700 Cooling Equipment Library

P14009-WSHP-D

Water-cooled chiller - Helical rotary

Comments:

Operating Mode	Capacity	Energy Rate
Cooling	10.00 tons	20.860 EER (compressor)
Heat Recovery	113.00 Mbh	2.770 COP (compressor)
Tank Charging	tons	kW/ton
Tank Chrg. & Heat Rec.	tons	kW/ton

Unloading Curves	Primary	Secondary
Power consumed	VS WSHP - Clg Mode	VS WSHP - Htg Mode
Ambient modification	WSHPGRND - Amb Mod	WSHPGRND - Amb Mod 2nd
Capacity	VS WSHP Clg Cap Mod	VS WSHP Htg Cap Mod

Load Shed Economizer	No
Evap Precooling	No
Fuel Source	Utility
Fuel type	Electric
Free cooling type	None
Fluid cooler type	
Thermal Storage	None
Tower/condenser	None

Pumps	Type	Full Load Consumption	Pump Head
Chilled water	Var vol chill water pump	0.000563kW/ton-ft wg	
Condenser water	None	0.00000kW	
Ht Rec or aux cond.	None	kW	
Free cooling pump	None		

Reset Based On	Reset Curve	Max Reset TD
Chilled water	None	
Condenser water	None	

Chilled water temp Design leaving	45.00°F
Chilled water temp Difference	10.00°F
Condenser temp design temp entering	75.00°F
Condenser temp min. operating	35.00°F
Condenser temp Difference	10.00°F
Reject Cond heat to ref	Ground loop
Reject Cond heat at water temp	120.00°F

Miscellaneous accessories
Cntl panel & interlocks - 1 KW

Library Members

Cooling Equipment

TRACE® 700 Cooling Equipment Library

90.1-07 Min ACHP AllHeat SP < 65 MBh

Air-cooled unitary - Air to air heat pump

Comments: Air Cooled, Electrically Operated HP, CV, All Heating SP

Operating Mode	Capacity	Energy Rate	Pumps	Type	Full Load Consumption	Pump Head
Cooling	tons	11.000 Packaged EER	Chilled water	None	0.000000kW	
Heat Recovery	14.40 Mbh/ton	7.700 Packaged EER	Condenser water	None	0.00000kW	
Tank Charging			Ht Rec or aux cond.	None	kW	
Tank Chrg. & Heat Rec.			Free cooling pump	None		

Unloading Curves	Primary	Secondary	Reset Based On	Reset Curve	Max Reset TD	Miscellaneous accessories
Power consumed	90.1 min Air to Air HP	90_1 AAHP Power Consumed C	Chilled water	None		Cntl panel & interlocks - 0.1 KW
Ambient modification	90.1 Min Air-Air HP	90_1 AAHP Ambient Relief Curv	Condenser water	None		
Capacity		90.1 HP Htg Cap Curve				

Load Shed Economizer	No	Chilled water temp Design leaving	44.00°F
Evap Precooling	No	Chilled water temp Difference	12.00°F
Fuel Source	Heating plant	Condenser temp design temp entering	95.00°F
Fuel type	Electric	Condenser temp min. operating	17.00°F
Free cooling type	None	Condenser temp Difference	0.00°F
Fluid cooler type	None	Reject Cond heat to ref	Heat rejection equipment
Thermal Storage	None	Reject Cond heat at water temp	
Tower/condenser	90.1 Min Air Cooled Condenser		

Package energy breakout	Primary fan	Secondary fan	Exhaust fan	Optional ventilation fan	Condenser fan
Included in full load energy rate	Yes	No	No	No	Yes

Apply same fans for heat recovery energy breakout: Yes

Fans

AF Centrifugal var freq drv

Fan type	Variable volume
Comments	Air foil Centrifugal with variable frequency drive
Full load energy	0.00022 kW/Cfm-in wg
Unloading curve	Fan Curve 9

Hydronic in heat pump fan

Fan type	Constant volume
Comments	Hydronic incremental heat pump fan
Full load energy	0.00024 kW/Cfm
Unloading curve	Fan Curve Straight Line

FC Centrifugal const vol

Fan type	Constant volume
Comments	Forward curved Centrifugal fan constant volume
Full load energy	0.00032 kW/Cfm-in wg
Unloading curve	Fan Curve Straight Line

Library Members

Heating Equipment

P14009-BACKUP

Comments	ELECTRIC HOT WATER BOILER EQ2051		
Category	Boiler		<u>Miscellaneous Accessories</u>
Heat Source	Utility		
Fuel Type	Electric		
Capacity		Mbh	
Energy Rate	100.000	Percent efficient	
Hot Water Pump	VV Hot Water Circ		
Hot Water Pump Full Load	0.00	kW	
Hot Water Leaving temp	120.00	°F	
Storage tank	None		
Unloading Curve	Htg Straight Line		

Default electric resistance

Comments	ROOFTOP ELECTRIC HEAT		
Category	Electric resistance		<u>Miscellaneous Accessories</u>
Heat Source	Utility		
Fuel Type	Electric		
Capacity		Mbh	
Energy Rate	100.000	Percent efficient	
Hot Water Pump	None		
Hot Water Pump Full Load	0.00	kW	
Hot Water Leaving temp		°F	
Storage tank	None		
Unloading Curve	Htg Straight Line		

Library Members

Misc. Equipment

VV Hot Water Circ

Comments	Hot water pump - variable volume	Cooling coil assignments	Heating coil assignments
Category	Water pump	Main	+ Main
Energy type	1.60000 hp	Direct evaporative	+ Preheat
Control type	Electricity	Indirect evaporative	+ Reheat
Full load energy	With equipment	Auxiliary	Mech. humidification
		Optional ventilation	+ Auxiliary
		System exhaust air	+ Optional ventilation
		Room exhaust air	+ Misc heating load
		Misc cooling load	+ Base utility htg load
		Base utility clg load	Absorption Chiller load

Var vol chill water pump

Comments	Chilled water pump - variable volume	Cooling coil assignments	Heating coil assignments
Category	Water pump	+ Main	+ Main
Energy type	0.00056 kW/ton-ft wg	Direct evaporative	+ Preheat
Control type	Electricity	Indirect evaporative	+ Reheat
Full load energy	With equipment	+ Auxiliary	+ Mech. humidification
		+ Optional ventilation	+ Auxiliary
		+ System exhaust air	+ Optional ventilation
		+ Room exhaust air	+ Misc heating load
		+ Misc cooling load	+ Base utility htg load
		+ Base utility clg load	+ Absorption Chiller load

90.1 Pump Riding the Pump Curve

Comments	5/2014 Bell and Gossett 1000gpm, 90ft,1510series	Cooling coil assignments	Heating coil assignments
Category	Water pump	+ Main	+ Main
Energy type	22.00000 Watt/gpm	Direct evaporative	+ Preheat
Control type	Electricity	Indirect evaporative	+ Reheat
Full load energy	With equipment	+ Auxiliary	+ Mech. humidification
		+ Optional ventilation	+ Auxiliary
		+ System exhaust air	+ Optional ventilation
		+ Room exhaust air	+ Misc heating load
		+ Misc cooling load	+ Base utility htg load
		+ Base utility clg load	+ Absorption Chiller load

Library Members

Thermal Storage

GLHE designed for 3F (2C) TD wellfield

Comments	Ground loop heat exchanger well field w/ 3F (2C) TD @DsnLoad		
Schedule	Heatpump	<u>Discharge Strategy</u>	<u>SpecificHeat</u>
Capacity	479.6 gal/ton	Control type	Optimize 1.0 Btu/lb-°F
Storage Type	Heat pump loop	Limit	0.0 tons <u>Density</u>
Losses	0 Percent	<u>Charging Strategy</u>	62.3 lb/cu ft
Warning level	0 Percent	Control type	Full charge <u>DesignDeltaT</u>
		Max loss	0.0 kW 3 °F

Heat Rejection

90.1 Min Air Cooled Condenser

Comments	For Air-cooled Centrifugal	<u>Coil load assignmen</u>
Capacity	100.00 Percent	+Main
Energy consumption	0.06 kW/ton	Direct evaporator
Low speed consumpt	14.30 Percent full load	+Indirect evaporator
Fluid type	Water	+Auxiliary
Condenser type	Air-cooled condenser	+Optional ventilation
Number of cells	1	+Misc cooling load
% Air at low Speed	50.00	
Approach Temp	10.00 °F	
Temp Range	10.00 °F	
Wet bulb Temp	78.00 °F	
Design water flow rate	3.00 gpm/ton	
Makeup water flow rate	0.00 gal/ton-hr	
Hourly Amb WB Offset	°F	
Unloading curve	Cooling Tower with 2-Speed Fan	